




Water and Wastewater  
Specialists

*VILLAGE OF MEDINA WWTF DISCHARGE QUALITY – November 2006*



*W a t e r   i s   o u r   B u s i n e s s*

Valley River, Inc.  
P. O. Box 943  
Millbrook, New York 12545

[www.vri-usa.com](http://www.vri-usa.com)

845-677-3839  
Toll Free: 800-880-6165  
Fax 845-677-3940

Millbrook

Camden

Oakfield



Water and Wastewater  
Specialists

Village Board  
Village of Medina  
600 Main Street  
Medina, New York 14103

Re: Wastewater Treatment Plant – Facilities Operation Report.

The Village's Facility treated on average 2,250,000 gallons per day in November. New York State Discharge Permit {NYS-SPDES} limits were met over the period. Below are the projects completed and other significant notes. Daily operations/maintenance activities conducted as scheduled.

***Projects and significant events of record.***

- Composting operation in process. 9.417 tons processed.
- Removed 12 cubic feet of grit from influent.
- Greased all equipment.
- Cleared blockage in East thickener.
- Completed painting lab counter top.
- Continued lab analysis study.
- Replaced ferric chloride lines.
- Repack moyno pumps.
- Repaired press room over head door.
- Repaired faucet in lab
- Adjusted chains on Aggie truck
- Flushed methane system.
- Replaced bad bearing on one RBC.

Steven C. Stauffer  
Regional Manager  
Valley River Inc.

**W a t e r   i s   o u r   B u s i n e s s**

Valley River, Inc.  
P. O. Box 943  
Millbrook, New York 12545

[www.vri-usa.com](http://www.vri-usa.com)

845-677-3839  
Toll Free: 800-880-6165  
Fax 845-677-3940

Millbrook

Camden

Oakfield