



# Clean Energy Communities Energy Study

**Prepared for:**

Village of Medina  
600 Main St  
Medina, NY 14103

Audit No: CEC300354

**Submitted by:**

L&S Energy Services  
58 Clifton Country Road, Suite 203  
Clifton Park, NY 12065

Date: 12/9/2024

For questions regarding this report, please contact [CEC@nyserda.ny.gov](mailto:CEC@nyserda.ny.gov).

We hope the findings of this report will assist you in making decisions about energy efficiency improvements in your facility. Thank you for your participation in this program.

#### **NOTICE**

This report was prepared pursuant to the Flexible Technical Assistance Program (Hereinafter "FlexTech") administered by the New York State Energy Research and Development Authority (hereinafter "NYSERDA"). The opinions expressed in this report do not necessarily reflect those of NYSERDA or the State of New York, and reference to any specific product, service, process, or method does not constitute an implied or expressed recommendation or endorsement of it by NYSERDA or the State of New York. Further, NYSERDA and the State of New York make no warranties or representations, expressed or implied, as to the fitness for a particular purpose or merchantability of any product, apparatus, or service, or the usefulness, completeness, or accuracy of any processes, methods, energy savings, or other information contained, described, disclosed, or referred to in this report. NYSERDA and the State of New York make no representation that the use of any product, apparatus, process, method, or other information will not infringe privately-owned rights and will assume no responsibility for any loss, injury, or damage resulting from, or occurring in connection with, the use of information contained, described, disclosed, or referred to in this report.

State of New York

Kathy Hochul, Governor

New York State Energy Research and Development Authority



## Consultant Disclaimer

The opinions expressed in this report do not necessarily reflect those of L&S Energy Services, C.J. Brown Energy P.C., The Daylight Savings Company, or Taitem Engineering P.C. (the Consultants), and reference to any specific product, service, process, or method does not constitute an implied or expressed recommendation or endorsement of it by the Consultants. Further, the Consultants make no warranties or representations, expressed or implied, as to the fitness for a particular purpose or merchantability of any product, apparatus, or service, or the usefulness, completeness, or accuracy of any processes, methods, energy savings, or other information contained, described, disclosed, or referred to in this report. The Consultants make no representation that the use of any product, apparatus, process, method, or other information will not infringe privately-owned rights and will assume no responsibility for any loss, injury, or damage resulting from, or occurring in connection with, the use of information contained, described, disclosed, or referred to in this report.

This report was prepared by:

C.J. Brown Energy, P.C.

4245 Union Rd, Buffalo, NY 14225

(716) 565-9190

## **Table of Contents**

|  |    |
|--|----|
| Executive Summary .....  | 1  |
| Present Energy Use and Cost .....  | 3  |
| Benchmarking Your Building .....   | 4  |
| Project Summary Table .....  | 5  |
| Note on Energy Project Implementation Costs .....                        | 6  |
| Greenhouse Gas Reductions for the Recommended Measures .....             | 7  |
| Existing Conditions .....  | 8  |
| Lighting Systems .....   | 8  |
| Heating Ventilating and Air Conditioning Systems.....                    | 8  |
| Water Heating System .....   | 8  |
| Energy Efficiency Measure Descriptions .....                             | 9  |
| EEM-1 Interior Lighting Retrofit.....                                    | 9  |
| EEM-2 Implement Deeper Setback.....                                      | 10 |
| EEM-3 Insulate Heating And Domestic Hot Water Pipes.....                 | 11 |
| EEM-4 Building Airflow Reduction .....                                   | 12 |
| EEM-5 Install Insulated Doors .....                                      | 13 |
| EEM-6 Exterior Lighting Retrofit .....                                   | 14 |
| EEM-7 Insulate Building Envelope .....                                   | 15 |
| EEM-8 Install Double Glazing.....  | 16 |
| EEM-9 Install A Tankless Water Heater.....                               | 17 |
| EEM-10 Switch Fuels For Heating Water .....                              | 18 |
| Building Electrification Measures.....                                   | 19 |
| BE-1 Install Clean Heating System - Air Source Heat Pump .....           | 20 |
| Appendix A .....   | 21 |
| Equipment Inventory.....   | 21 |
| Appendix B .....   | 22 |
| Energy Use and Cost Summary .....  | 22 |
| Utility Bill Data.....   | 22 |
| Appendix C .....   | 25 |
| EEM Calculations.....  | 25 |
| Appendix D .....   | 38 |
| Assumptions/Data Used to Develop Energy and Dollar Savings Figures ..... | 38 |
| Appendix E .....   | 41 |
| Clean Heating and Cooling Technology Overview .....                      | 41 |
| Appendix F .....   | 45 |
| Energy Savings Summaries .....   | 45 |

## Executive Summary

In consideration of NYSERDA's objectives, the primary focus of this Energy Study is the evaluation of energy efficient electric building technologies. Limited opportunities that reduce fossil fuel use may be considered, however, the evaluation of new systems and equipment that utilize fossil fuels is excluded from the analysis contained herein and as such will not be recommended as energy efficiency improvements. The replacement of systems and equipment that utilize fossil fuels are not eligible for Clean Energy Communities Funding.

This study was performed to understand how your facility is currently using energy and identify ways to reduce energy use and operating expenses.

Specific areas of concern that were identified by the owner for evaluation include drafty windows throughout both buildings. The Firehouse in particular gets very cold in the winter, suspected due to poor insulation. Additionally, the kitchen window in the Firehouse lets in water, suggesting faulty seals, that has resulted in some water damage to the inside windowsill.

The following energy efficiency measures (EEMs) and observations to reduce energy use were identified during the site visit:

- Interior Lighting Retrofit - Replace all interior lamps with LEDs.
- Implement Deeper Setback - Program thermostats to a deeper setback temperature during unoccupied hours.
- Insulate Heating and Domestic Hot Water Pipes - Insulate piping in unconditioned spaces to help heating water and domestic hot water retain its heat until it is used.
- Building Airflow Reduction - Reduce air infiltration with airsealing around exterior doors and windows.
- Install Insulated Doors - Replace the poorly insulated glass doors on the catwalk with better insulated models to reduce heat loss.
- Exterior Lighting Retrofit - Replace all exterior lamps with LEDs.
- Insulate Building Envelope - Insulate the exterior wall of the Police Chief Office to reduce heat loss in the room.
- Install Double Glazing - Replace the Firehouse kitchen window with a better insulating and better fitting model to reduce heat loss and prevent further water damage.
- Install a Tankless Water Heater – Replace the Village Hall natural gas domestic hot water heating system with an electric tankless water heater.
- Switch Fuels for Heating Water - Replace the natural gas tankless water heater in the Firehouse with an electric model.

- Install Clean Heating System - Air Source Heat Pump - Replace the natural gas heating system with an air source heat pump to electrify a portion of the building's heating system.

These Energy Efficiency Measures are summarized in the Project Summary Table below and discussed in more detail in the Energy Efficiency Measures section of this report.

## Present Energy Use and Cost

The energy use for your facility has been compiled to calculate the Energy Cost Index and the Energy Use Intensity.


- The Energy Cost Index (ECI) is the total cost of energy divided by the conditioned floor area and is shown as dollars per square foot per year.
- The Energy Use Intensity (EUI) is the total heat content of energy divided by the conditioned floor area and is shown in units of one thousand Btus (kBtu) per square foot per year.

### Energy Cost Index


|                   |                  |                |                       |
|-------------------|------------------|----------------|-----------------------|
| Electricity       | \$ 11,154        | \$ 0.52        | \$/sq.ft./year        |
| Natural Gas       | \$ 4,947         | \$ 0.23        | \$/sq.ft./year        |
| <b>Total Cost</b> | <b>\$ 16,102</b> | <b>\$ 0.75</b> | <b>\$/sq.ft./year</b> |

### Energy Use Intensity

|                         |                  |             |                         |
|-------------------------|------------------|-------------|-------------------------|
| Electricity             | 355 mmBtu        | 16.6        | kBtu/sq.ft./year        |
| Natural Gas             | 593 mmBtu        | 27.7        | kBtu/sq.ft./year        |
| <b>Total Energy Use</b> | <b>947 mmBtu</b> | <b>44.2</b> | <b>kBtu/sq.ft./year</b> |



**Energy Cost Index \$ 0.75 /sf/yr.**



**Energy Use Intensity 44.2 kBtu/sf/yr.**

## **Benchmarking Your Building**

The EPA's ENERGY STAR Portfolio Manager website allows you to upload energy use information and compare your energy use to that of other buildings of similar use. Portfolio Manager generates a benchmark score that indicates your performance. A benchmark score of 50 indicates average performance while a score of 75 or higher would earn the Energy Star designation. You can use the website to track your energy use over time and document the success of your energy conservation efforts.

You can find the Portfolio Manager at:

<https://www.energystar.gov/buildings/facility-owners-and-managers/existing-buildings/use-portfolio-manager>



## Project Summary Table

| Energy Efficiency Measures             |                |   |  | \$ Savings & Cost    |                  |                        |
|--|----------------|---|--|----------------------|------------------|------------------------|
| EEM #                                  | Measure Status | EEM Description                               | Reduction in Greenhouse Gas Emissions (Lbs. CO2e/Year) | Total Annual Savings | Install Costs    | Simple Payback (years) |
| EEM-1                                  | R              | Interior Lighting Retrofit                    | 11,758   | \$ 1,582             | \$ 3,406         | 2.2                    |
| EEM-2                                  | R              | Implement Deeper Setback                      | 1,143  | \$ 75                | \$ 400           | 5.4                    |
| EEM-3                                  | R              | Insulate Heating And Domestic Hot Water Pipes | 277  | \$ 18                | \$ 182           | 10.0                   |
| EEM-4                                  | R              | Building Airflow Reduction                    | 2,924  | \$ 192               | \$ 2,196         | 11.4                   |
| EEM-5                                  | R              | Install Insulated Doors                       | 1,011  | \$ 66                | \$ 790           | 12.0                   |
| EEM-6                                  | R              | Exterior Lighting Retrofit                    | 356  | \$ 19                | \$ 300           | 15.5                   |
| EEM-7                                  | R              | Insulate Building Envelope                    | 228  | \$ 15                | \$ 236           | 15.9                   |
| EEM-8                                  | RNE            | Install Double Glazing                        | 300  | \$ 20                | \$ 998           | 50.7                   |
| EEM-9                                  | NR             | Install A Tankless Water Heater               | 466  | \$ 25                | \$ 3,176         | 124.8                  |
| EEM-10                                 | NR             | Switch Fuels For Heating Water                | 212  | \$ 9                 | \$ 3,176         | 361.2                  |
| <b>All Energy Efficiency Measures:</b> |                |   | <b>18,673</b>  | <b>\$ 2,021</b>      | <b>\$ 14,860</b> | <b>7.4</b>             |
| <b>Total of Recommended Measures:</b>  |                |   | <b>17,995</b>  | <b>\$ 1,987</b>      | <b>\$ 8,508</b>  | <b>4.3</b>             |

### Measure Status Explanation:

**(I) - Implemented:** Measure has been installed

**(R) - Recommended:** Energy saved with a reasonable payback (within measure life)

**(NR) - Not Recommended:** When payback exceeds measure life and equipment is not at end of life

**(RME) - Recommended Mutually Exclusive:** Energy is saved and recommended over other options for a particular measure

**(ME) - Mutually Exclusive:** Non-recommended option(s) to a Recommended Mutually Exclusive (RME) measure

**(RNE) - Recommended Non-Energy:** Recommended based on other, non-energy factors such as comfort, water savings or equipment at end of life

**(RS) - Recommended for Further Study:** For measures that require analysis beyond the scope of this program.

**(BE) - Building Electrification:** Measures that should be considered based on greenhouse gas reductions, eliminating on-site use of fossil fuels, or other sustainability factors

| Building Electrification Measures     |                |   |  | \$ Savings & Cost    |                  |                        |                      |                                 |
|---------------------------------------|----------------|---|--|----------------------|------------------|------------------------|----------------------|---------------------------------|
| EEM #                                 | Measure Status | Building Electrification Measure Descriptions       | Reduction in Greenhouse Gas Emissions (Lbs. CO2e/Year) | Total Annual Savings | Install Costs    | Simple Payback (years) | Estimated Incentives | Simple Payback after incentives |
| BE-1                                  | NR             | Install Clean Heating System - Air Source Heat Pump | (1,572)  | (\$ 568)             | \$ 13,192        | n/a                    | \$ 3,720             | n/a                             |
| <b>All Measures:</b>                  |                |   | <b>(1,572)</b>   | <b>(\$ 568)</b>      | <b>\$ 13,192</b> | <b>n/a</b>             | <b>\$ 3,720</b>      | <b>n/a</b>                      |
| <b>Total of Recommended Measures:</b> |                |   | <b>0</b>   | <b>\$ 0</b>          | <b>\$ 0</b>      |                        | <b>\$ 0</b>          |                                 |

Simple Payback Period is the length of time it will take to recover the initial capital investment from the energy savings of the new equipment. The Simple Payback Period is calculated by dividing the initial installed cost by the annual energy cost savings. For example, an energy-saving measure that costs \$5,000 and saves \$2,500 per year has a Simple Payback Period of \$5,000 divided by \$2,500 or 2 years.

**Note on Energy Project Implementation Costs**

The "Project Costs" shown in this report for each Energy Efficiency Measure represent an initial estimate of the implementation cost. Unless otherwise noted in the Energy Efficiency Measure description, these costs reflect a preliminary estimate of material and labor. There may be other variables associated with your specific project that will impact the true project costs that the study may not capture. Other external factors that may impact true project costs and payback include material availability, vendor scheduling, access within the facility, general inflation, available measure incentives, and other unknown factors and conditions. For measures which significantly impact your building's usage, it is also important to determine any potential utility rate and/or tariff changes, those of which are beyond the scope of this report. We recommend that you seek several quotes from qualified vendors prior to implementation.

### Greenhouse Gas Reductions for the Recommended Measures

Reducing your energy use will reduce the release of greenhouse gases associated with the use of fossil fuels and the production of electricity. If the measures recommended in this report are implemented, the following reductions of greenhouse gases can be expected:

|             |        |         |        |                       |
|-------------|--------|---------|--------|-----------------------|
| Electricity | 13,092 | kWh =   | 15,187 | pounds CO2 equivalent |
| Natural Gas | 240    | therm = | 2,808  | pounds CO2 equivalent |
|             |        |         | <hr/>  |                       |
|             |        |         | 17,995 | pounds CO2 equivalent |
|             |        |         | 9.5%   | reduction             |

Emissions factors are used to translate the energy savings data from energy efficiency and renewable generation projects into annual GHG emissions reduction values. NYSERDA uses emission factors derived from U.S. Environmental Protection Agency (EPA) emission coefficients to calculate emissions from onsite fuel. The CO2e values represent aggregate CO2, CH4, and N2O emissions.

## **Existing Conditions**

The site is comprised of two buildings: the Village Hall and the Firehouse serving the Village of Medina. The Village Hall holds the Police Department, Court, and Division of Code Enforcement on the 1st, 2nd, and 3rd floors, respectively. The 2nd floor also holds the Police Chief's office, the Police Gym, and the Village Clerk-Treasurer's office. The Firehouse holds the Fire Department: the garage on the ground floor, and offices, training rooms, break rooms, and storage on the second floor.

The site consists of two buildings totaling 21,411 square feet. The first building, the Village Hall, was originally constructed in 1908 and has 3 floors. The interior walls are finished plaster and drywall with unknown insulation, and the exterior walls have the well maintained original sandstone finish. The Firehouse, built in the 19050's, has similar interior walls, but with an exterior brick finish. Both buildings have a flat roof with a membrane exterior surface, fiberglass insulation and an interior finished ceiling of acoustic tile.

The Village Hall windows are mostly single hung, single pane windows with wooden frames. There are some decorative single pane fixed windows. The Firehouse windows are all fixed double pane. All exterior doors are steel, except for the front entrance double doors, which are wood. Many of the exterior doors have damaged weatherstripping.

Major energy end uses include the heating, cooling, and interior lighting systems. The first floor of the Village Hall and the entire Firehouse is occupied 24/7 by some emergency response staff. As a result, the HVAC system maintains occupied conditions in these areas 24/7. On the second and third floors of the Village Hall, day-to-day staff is present during regular working hours. In these areas, the HVAC maintains occupied conditions for 8 hours on weekdays, totaling 40 hours a week.

Winter space temperatures are on average maintained at 66°F and are setback to 65°F during unoccupied periods in applicable areas. In the summer, temperatures are maintained on average at 71°F during occupied hours and 75°F during unoccupied periods. All areas utilize programmable thermostats except for the Fire Truck Bay, which is on a nonprogrammable heat-only thermostat.

### **Lighting Systems**

The interior lighting systems of these buildings mostly rely on incandescent lamps. The exterior lighting systems, while mostly LED, have a couple faulty photocell sensors.

### **Heating Ventilating and Air Conditioning Systems**

The Village Hall uses three furnaces and a boiler to meet heating needs, while the Firehouse uses a single furnace and a unit heater in the garage. All heating systems are natural gas fired. There are three air conditioning units serving cooling to the majority of both buildings.

### **Water Heating System**

The Village hall uses a storage type natural gas fired domestic hot water heating system, and the Firehouse uses a tankless natural gas fired system.

See Appendix D for further details regarding the energy calculations performed for this study.

## Energy Efficiency Measure Descriptions

### **EEM-1 Interior Lighting Retrofit**

|                              |                  |   |
|------------------------------|------------------|---|
| Electric Savings:            | \$ 1,778         | 12,703 kWh per year<br>5.5 kW demand      |
| Fuel Savings:                | (\$ 196)         | (25.4) MMBtu fuel per year<br>Natural Gas |
| <b>Total Annual Savings:</b> | <b>\$ 1,582</b>  |   |
| <b>Project Cost:</b>         | <b>\$ 3,406</b>  |   |
| <b>Simple Payback:</b>       | <b>2.2 years</b> |   |

#### Introduction:

Lighting usually represents a major portion of a facility's electricity use, and given the continuous hours of use, it contributes to the peak electric demand each month. Taking steps to improve the efficiency of your lighting will reduce both the total electric energy used and lower your peak electric demand. Lighting retrofit projects now consist of installing Light Emitting Diode, or LED, light sources in all fixtures. Some fixtures, such as indoor fluorescent fixtures, can be retrofitted to use T-8 replacement lamps, but most fixtures should simply be replaced with LED fixtures. Energy savings of 50% are common when replacing fluorescent and HID light sources with LED sources.

LED light sources for interior applications should list their color on the label; this is expressed in degrees Kelvin, or °K. Lights with higher values will be more blue in color and may not be appropriate for indoor use. Look for values between 3500 and 4000°K for "cool white" light. For spaces where a warmer color of light is desired, select lights with values between 2700 and 3000°K.

#### Recommendation:

Retrofit interior fluorescent fixtures and replace other fixtures as indicated in the lighting calculations and the Equipment Inventory, both of which may be found in the Appendix.

LED lamps and fixtures should be Energy Star labeled or listed with the Design Lights Consortium (DLC). Your utility incentive program may have other requirements that must be met in order to qualify for incentives.

## EEM-2 Implement Deeper Setback

|                              |                  |  |
|------------------------------|------------------|--|
| Electric Savings:            | \$ 2             | 36 kWh per year<br>0.0 kW demand       |
| Fuel Savings:                | \$ 72            | 9.4 MMBtu fuel per year<br>Natural Gas |
| <b>Total Annual Savings:</b> | <b>\$ 75</b>     |  |
| <b>Project Cost:</b>         | <b>\$ 400</b>    |  |
| <b>Simple Payback:</b>       | <b>5.4 years</b> |  |

### Introduction:

Proper temperature control is important in order to minimize energy costs. Maintaining space temperatures within a reasonable range during occupied periods and reliably reducing the amount of heating and cooling energy during unoccupied periods should be the goal for your temperature control system.

Facilities that are occupied only on weekdays can maintain a lower space temperature setpoint on weekends. Programmable thermostats are available that permit full 7 day schedules to be defined. 5-2 or 5-1-1 thermostats use the same schedule for all weekdays and provide one or two schedules for weekend days.

### Recommendation:

Reprogram the thermostats to setback temperature of 60 degrees for heating and 80 degrees for cooling during unoccupied periods in spaces that aren't used 24/7. This should include the 2nd and 3rd floors of the Village Hall.

### EEM-3 Insulate Heating And Domestic Hot Water Pipes

|                              |                   |  |
|------------------------------|-------------------|--|
| Electric Savings:            | (\$ 0)            | 0 kWh per year<br>0.0 kW demand        |
| Fuel Savings:                | \$ 18             | 2.4 MMBtu fuel per year<br>Natural Gas |
| <b>Total Annual Savings:</b> | <b>\$ 18</b>      |  |
| <b>Project Cost:</b>         | <b>\$ 182</b>     |  |
| <b>Simple Payback:</b>       | <b>10.0 years</b> |  |

#### Introduction:

Heat is distributed through the building by pipes containing hot water or steam. Heating distribution system pipes lose heat to the surrounding space. If the heat is lost to an area that does not require heating, the drop in system efficiency can be significant. Un-insulated pipes in conditioned space may also overheat the space, wasting energy and causing comfort problems. All heating distribution system pipes located in unconditioned space should be insulated.

Domestic hot water (DHW) is water that is heated for hand washing, showering, dish washing, laundry, etc. Domestic hot water pipes lose heat to the surrounding space. This loss is significant in facilities with recirculating hot water systems, or in facilities that use hot water for a large portion of the day. In a recirculating system, all domestic hot water pipes should be insulated. In a non-recirculating system, domestic hot water pipes within eight feet of the water heater should be insulated.

#### Recommendation:

Insulate all exposed heating pipes that are located in unconditioned space. Insulate the first eight feet of domestic hot water piping after the water heater. Insulation thickness should be per the New York State Energy Conservation Construction Code, and should be pre-formed fiberglass pipe insulation with protective jacketing.

Install 1 in. insulation on (8 ft.) of 0.75 in. Dull Copper DHW pipe on the water heater in the Village Hall, 1 in. insulation on (8 ft.) of 0.75 in. Dull Copper DHW pipe on the water heater in the Firehouse, and 1 in. insulation on (10 ft.) of 0.75 in. Dull Copper Hot Water pipe on the boiler in the Village Hall.

## EEM-4 Building Airflow Reduction

|                              |                   |   |
|------------------------------|-------------------|---|
| Electric Savings:            | \$ 0              | 0 kWh per year<br>0.0 kW demand         |
| Fuel Savings:                | \$ 192            | 24.9 MMBtu fuel per year<br>Natural Gas |
| <b>Total Annual Savings:</b> | <b>\$ 192</b>     |   |
| <b>Project Cost:</b>         | <b>\$ 2,196</b>   |   |
| <b>Simple Payback:</b>       | <b>11.4 years</b> |   |

### Introduction:

Reducing air infiltration is vital to creating a more energy efficient building. The purpose of air sealing is to create an effective air tight seal on the building envelope. This will reduce the amount of air flow and heat loss from conditioned to un-conditioned space. Factors that cause high air flow rates include the size and number of openings that connect the conditioned and unconditioned spaces and pressure differences between the interior and exterior of the building. The differences in pressures are typically caused by stack effect, wind, and temperature differences between the inside and outside of the building. An air sealing contractor will use special diagnostic tools to pinpoint and seal hidden air leaks, typically hidden under the attic insulation.

Sealing the largest openings at the highest and lowest levels first is the most effective way to reduce unwanted air flow. These types of openings may include attic access doors, large mechanical chases that house ductwork and vent flues, and wall bypasses. Wall bypasses are holes created by irregular framing and can be found in interior and exterior wall systems. Smaller openings from wire holes, plumbing lines, and gaps around windows, doors and chimney flues are equally as important. Materials that should be considered for different applications are caulks, expanding foam, non-expanding foam, weather-stripping, and rigid insulation board.

### Recommendation:

All exterior man doors should have damaged weatherstripping replaced. All garage doors also have damaged weatherstripping and thresholds. Replace the weather stripping around the sides and bottom of each garage door. Also install threshold seal strips along the garage floor ground where the bottom of the door closes. The new strips should be aligned to ensure a tight seal.

Additionally, most of the windows in both buildings have gaps in caulk seams. Remove and replace cracked caulkwork around all windows.



## EEM-5 Install Insulated Doors

|                              |                   |  |
|------------------------------|-------------------|--|
| Electric Savings:            | \$ 2              | 38 kWh per year<br>0.0 kW demand       |
| Fuel Savings:                | \$ 64             | 8.3 MMBtu fuel per year<br>Natural Gas |
| <b>Total Annual Savings:</b> | <b>\$ 66</b>      |  |
| <b>Project Cost:</b>         | <b>\$ 790</b>     |  |
| <b>Simple Payback:</b>       | <b>12.0 years</b> |  |

### Introduction:

Single pane wooden frame or metal frame doors can be very inefficient. Heat loss due to conduction through single pane glass can be very high. Also heat loss due to air infiltration past loose fitting or worn out frames can increase the cost of energy to heat this air. Drafts can also occur causing discomfort to occupants. The installation of insulated replacement doors will reduce these heating loads.

Energy efficient doors are built with thermal breaks and insulated cores to reduce conduction heat losses. Weather stripping along the perimeter of the door minimizes the infiltration of unconditioned air.

### Recommendation:

Replace the two glass doors on the catwalk connecting the Firehouse and the Village Hall. The new door should be tight fitting and completely caulked around the wall seams. Weatherstripping should be installed around all edges. The bottom of each door should have sturdy door sweeps installed. The door itself should be filled with a urethane or polystyrene foam. The listed R-value should be no lower than 5. Any glazed area should be double glazed with safety glass, and should comprise no more than 25% of the total door area.

## EEM-6 Exterior Lighting Retrofit

|                              |                   |                         |
|------------------------------|-------------------|-------------------------|
| Electric Savings:            | \$ 19             | 307 kWh per year        |
|                              |                   | 0.0 kW demand           |
| Fuel Savings:                | \$ 0              | 0.0 MMBtu fuel per year |
| <b>Total Annual Savings:</b> | <b>\$ 19</b>      |                         |
| <b>Project Cost:</b>         | <b>\$ 300</b>     |                         |
| <b>Simple Payback:</b>       | <b>15.5 years</b> |                         |

### Introduction:

High Intensity Discharge (HID) fixtures are often used outdoors for parking areas, grounds illumination and outdoor security lighting. HID fixtures may use mercury vapor, high pressure sodium or metal halide lamps that resemble incandescent lamps in outward appearance but require a ballast to operate. Of these, high pressure sodium and metal halide are the most common. All HID lamp types are point light sources, so HID fixtures usually have a reflector to redirect light into the desired distribution pattern. HID fixtures do not provide very uniform lighting in exterior applications.

Light Emitting Diode (LED) fixtures use an array of LEDs, which are solid state devices that produce light. The array is designed to distribute light into the desired distribution pattern, utilizing the directional nature of LEDs to achieve very uniform light levels without "hot spots" that are common with HID fixtures. This enables LED fixtures to provide the required illumination levels with lower overall energy use than traditional HID fixtures. LED exterior fixtures have replaced HID fixtures in the marketplace because they are more efficient, more compact, and they last longer.

### Recommendation:

The two exterior lighting fixtures were observed as powered during the day, suggesting faulty photocell sensors. Replace selected exterior fixtures as indicated in the lighting calculations and the Equipment Inventory, both of which may be found in the Appendix.

LED fixtures should be Energy Star labeled or listed with the Design Lights Consortium (DLC). Your utility incentive program may have other requirements that must be met in order to qualify for incentives.

## EEM-7 Insulate Building Envelope

|                              |                   |  |
|------------------------------|-------------------|--|
| Electric Savings:            | \$ 1              | 9 kWh per year<br>0.0 kW demand        |
| Fuel Savings:                | \$ 14             | 1.9 MMBtu fuel per year<br>Natural Gas |
| <b>Total Annual Savings:</b> | <b>\$ 15</b>      |  |
| <b>Project Cost:</b>         | <b>\$ 236</b>     |  |
| <b>Simple Payback:</b>       | <b>15.9 years</b> |  |

### Introduction:

Heat moves from areas of high temperature to areas of low temperature. As the temperature difference between a heated and an unheated space becomes greater, so does the rate of heat transfer. Insulation reduces the rate of heat transfer by filling the space with material that is less conductive than what is currently there. The effectiveness of insulation is measured by R-value, which is the resistance to heat transfer. As the R-value increases, the rate at which heat is transferred decreases.

Insulation can be installed in enclosed spaces, such as wall cavities, cathedral ceiling cavities, and floored attic cavities. It can also be installed in unfloored attics, which can accommodate greater thickness resulting in higher R-value. When insulation is combined with air sealing, convective air currents that circulate air within cavities and through insulation are reduced, which increases the effective R-value of the insulation.

### Recommendation:

The fire chief office gets frigid during the winter, likely due to the poorly insulated wall area where a window used to be. The R-value of this wall is likely much lower than the rest of the building. This calculation assumes R-value 10 for the wall- just below the standard 13, as it was noted during the site visit interview that there can be frost build up in the room. An insulation study may be useful to determine the true state of insulation throughout the Firehouse offices.

Add insulation equal to or greater than R-10 to 200 square feet of the fire chief office wall.

## EEM-8 Install Double Glazing

|                              |               |  |
|------------------------------|---------------|--|
| Electric Savings:            | \$ 0          | 0 kWh per year<br>0.0 kW demand        |
| Fuel Savings:                | \$ 20         | 2.6 MMBtu fuel per year<br>Natural Gas |
| <b>Total Annual Savings:</b> | <b>\$ 20</b>  |  |
| <b>Project Cost:</b>         | <b>\$ 998</b> |  |
| <b>Simple Payback:</b>       | <b>50.7</b>   | <b>years</b>                           |

### Introduction:

Single pane wooden or metal frame windows can be very inefficient. Heat loss due to conduction through single pane windows can be very high. New windows utilize two panes of glass instead of one. Glass performance is measured in two ways Solar Heat Gain Coefficient (SHGC) or Visible Transmittance (VT). SHGC is the amount of solar gain transmitted through a window into the building. VT refers to the amount of visible light that moves through the glass from exterior to interior. These two factors can be altered for a higher performing window by adding Low-E coatings and spacers with gas. The overall thermal performance of windows is generally assigned a u-value. This measurement considers all parts of a window. These parts include the frame, sash, and glass. The installation of windows with double glazing will reduce infiltration and conduction losses.

### Recommendation:

The kitchen window in the Firehouse is poorly insulated and contributes to significant heat loss in the building. Additionally, the window lets in water which has overtime caused water damage to the surrounding wall and windowsill. Install a new double glazed window with low-e coatings. Be sure that window is fully caulked on the exterior and interior where they meet the existing building structure. The EPA and DOE have developed stringent standards for windows. Windows that meet these standards can earn the Energy Star Label. Replacement window should bear the Energy Star label.

Despite its long payback period, this measure is still recommended for implementation. The building owner reported that this area of the Firehouse is particularly cold due to the window, and does not retain heat. Additionally, the water damage allowed by the window will grow over time, and result in more devastating damage.

## EEM-9 Install A Tankless Water Heater

|                              |                    |  |
|------------------------------|--------------------|--|
| Electric Savings:            | (\$ 11)            | (77) kWh per year<br>(0.0) kW demand   |
| Fuel Savings:                | \$ 36              | 4.7 MMBtu fuel per year<br>Natural Gas |
| <b>Total Annual Savings:</b> | <b>\$ 25</b>       |  |
| <b>Project Cost:</b>         | <b>\$ 3,176</b>    |  |
| <b>Simple Payback:</b>       | <b>124.8 years</b> |  |

### Introduction:

Storage type water heaters maintain a tank of hot water continuously, so that hot water is available when it is needed. These storage tanks continuously lose heat through the outer surfaces of the tank, even though they are insulated. Water heaters with gas, oil or propane burners also lose heat through the flue when the burner is not firing.

Tankless water heaters produce hot water only when there is a demand for it. They sense the flow of water and quickly heat the water as long as there is flow, or demand, for hot water. Tankless water heaters are available with electricity, natural gas or propane as energy sources. They are best located close to the point where hot water is used.

### Recommendation:

Replace the present storage type water heater serving the Village Hall with an electric tankless water heater.

This measure is not recommended as the payback period extends beyond its effective useful life.

## EEM-10 Switch Fuels For Heating Water

|                              |                    |  |
|------------------------------|--------------------|--|
| Electric Savings:            | (\$ 11)            | (77) kWh per year<br>(0.0) kW demand   |
| Fuel Savings:                | \$ 20              | 2.6 MMBtu fuel per year<br>Natural Gas |
| <b>Total Annual Savings:</b> | <b>\$ 9</b>        |  |
| <b>Project Cost:</b>         | <b>\$ 3,176</b>    |  |
| <b>Simple Payback:</b>       | <b>361.2 years</b> |  |

### Introduction:

The cost of heating water may be reduced by switching to a fuel that offers a lower cost and/or higher efficiency equipment. A fuel switch is also one way to increase system capacity if the current system cannot meet your demand for hot water. High efficiency condensing water heaters using natural gas or propane are available in tankless and storage-type configurations. Electric heat pump water heaters are another high efficiency option. Small electric waters located at the point of use may also be more energy efficient than distant oversized storage type systems.

The new systems will usually require the installation of power and natural gas or propane piping. Fossil fuel systems must be vented to the outdoors and condensing systems must be piped to a suitable drain to remove condensate. Fossil fuel fired systems must be located in a space with access to the outdoors. All state and local regulations must be adhered to for the safe and proper installation of these units.

### Recommendation:

Replace the present natural gas tankless water heater serving the Firehouse with an electric tankless water heater.

This measure is not recommended as its payback period extends beyond its effective useful life.

## **Building Electrification Measures**

The following measures evaluate the impact of replacing your existing fossil-fuel heating systems with clean heating and cooling systems powered by electricity. For space heating, air source heat pumps and ground source heat pumps are available in various system types to provide both heating and cooling to your building.

Fossil fuel-fired water heaters may also be replaced with heat pump water heaters to further reduce your use of fossil fuels.

When combined with renewable electricity, heat pump systems can eliminate the use of fossil fuels in your building.

See Appendix E - Benefits Of Clean Heating and Cooling (CHC) Technologies for more information on these system types.

## BE-1 Install Clean Heating System - Air Source Heat Pump

|                              |                  |                   |                               |
|------------------------------|------------------|-------------------|-------------------------------|
| Electric Savings:            | (\$ 1,246)       | (10,261)          | kWh per year                  |
|                              |                  | (1.7)             | kW demand                     |
| Fuel Savings:                | \$ 679           | 88.1              | MMBtu fuel per year           |
|                              |                  |                   | Natural Gas                   |
| <b>Total Annual Savings:</b> | <b>(\$ 568)</b>  |                   |                               |
| <b>Project Cost:</b>         | <b>\$ 13,192</b> |                   |                               |
| <b>Simple Payback:</b>       | <b>n/a</b>       | <b>years, n/a</b> | <b>years after incentives</b> |

### Introduction:

Air source heat pumps (ASHP) provide both heating and cooling using electricity to exchange energy with the outdoor air. Existing buildings may be retrofitted with various heat pump technologies to reduce or eliminate their dependence on fossil fuels for space heating. System options range from centrally-ducted cold climate air source heat pumps and mini-split heat pumps to large variable refrigerant flow systems having multiple indoor units supported by each outdoor unit.

At very cold outdoor air conditions, air source heat pumps may require supplemental heat to meet your building's heating load. Supplemental heat may be in the form of electric resistance heat or your existing fossil-fueled heating system, if it remains in service. The extent to which an ASHP system reduces your fossil fuel use will depend on the exact design and control of your new system.

### Recommendation:

Replace your natural gas heating system with a central ducted air source heat pump system serving the Firehouse garage. The system type is: Central Ducted ASHP with Integrated/ Modulating controls sized to 16% of the building heating load. The heat pumps are assumed to be rated at 13.05 EER full load cooling, 15 SEER. The heat pumps are assumed to be rated at 10 HSPF for heating, which may be adjusted to 2.59 COP. Be sure to specify heat pumps that meet NEEP requirements (Northeast Energy Efficiency Partnerships). See [https://ashp.neep.org/#!/product\\_list/](https://ashp.neep.org/#!/product_list/) for current models that meet these requirements.

This measure is not recommended as the payback period extends beyond its effective useful life.



# Appendix A

## Equipment Inventory

| Heating and Air Conditioning Equipment |     |             |               |              |                  |       |      |                 |      |
|--|-----|-------------|---------------|--------------|------------------|-------|------|-----------------|------|
| Unit Type                              | Qty | Make/Model  | Heating kBtuh | Heating Eff. | Cooling Capacity | Units | EER  | Serves/Location | Year |
| Furnace                                | 1   | York        | 120           | 96%          |                  |       |      | Firehouse       | 2016 |
| Unit Heater                            | 1   | Trane       | 200           | 80%          |                  |       |      | Fire Truck Bay  | 1995 |
| Furnace                                | 1   | ICP         | 120           | 98%          |                  |       |      | Police Chief    | 2011 |
| Furnace                                | 1   | Luxaire     | 80            | 95%          |                  |       |      | Court Room      | 2017 |
| Furnace                                | 1   | ICP         | 100           | 80%          |                  |       |      | Police Dept.    | 2002 |
| Air Conditioner                        | 3   | Luxaire     |               |              | 3                | tons  | 11.0 | Both Buildings  |      |
| Boiler                                 | 1   | Weil McLain | 200           | 84%          |                  |       |      | Village Hall    | 2016 |

| Domestic Hot Water |     |            |          |       |             |                         |      |                 |      |
|--------------------|-----|------------|----------|-------|-------------|-------------------------|------|-----------------|------|
| Unit Type          | Qty | Make/Model | Capacity | Units | Fuel Type   | Storage Capacity (gal.) | Eff. | Serves/Location | Year |
| Tankless           | 1   | Navien     | 200      | kbtuh | Natural Gas | 0                       | 96%  | Firehouse       | 2021 |
| Storage            | 1   | Reliance   | 35.0     | kbtuh | Natural Gas | 40                      | 80%  | Town Hall       | 2008 |

| Interior Lighting Fixtures |                           |     |                           |             |             |              |   |     |                         |              |             |
|----------------------------|---------------------------|-----|---------------------------|-------------|-------------|--------------|---|-----|-------------------------|--------------|-------------|
| Existing Fixtures          |                           |     |                           |             |             | Recommended  | Recommended Interior Lighting Efficiency Improvements |     |                         |              |             |
| Line #                     | Area                      | Qty | Present Lighting Type     | Lamps /fixt | Watts /Fixt | Control Type | Measure Type  | Qty | Proposed Lighting Type  | Lamp s /fixt | Watts /Fixt |
| 1                          | Fire Offices              | 2   | 4' 32w T8 EE Mag. bal.    | 2           | 71          | No Change    | LED Relamp  | 2   | 4' LED T8 2000 lu. 14W  | 2            | 28          |
| 2                          | Fire Hall Hallways        | 8   | 4' 32w T8 EE Mag. bal.    | 2           | 71          | No Change    | LED Relamp  | 8   | 4' LED T8 2000 lu. 14W  | 2            | 28          |
| 3                          | Fire Mop Closet           | 1   | 2' 17w T8 Elec. bal.      | 3           | 47          | No Change    | LED Relamp  | 1   | 2' LED tube 1150 lu. 7W | 3            | 21          |
| 4                          | Fire Store Closet         | 1   | 4' 32w T8 EE Mag. bal.    | 3           | 110         | No Change    | LED Relamp  | 1   | 4' LED T8 2000 lu. 14W  | 3            | 42          |
| 5                          | Fire Training Room        | 8   | 4' 32w T8 EE Mag. bal.    | 2           | 71          | No Change    | LED Relamp  | 8   | 4' LED T8 2000 lu. 14W  | 2            | 28          |
| 6                          | Fire Kitchen (Pucks)      | 4   | 11w CFL Spiral Elec. bal. | 1           | 11          | No Change    | LED Relamp  | 4   | 4' LED T8 2000 lu. 14W  | 1            | 14          |
| 7                          | Fire Kitchen              | 2   | 4' 32w T8 EE Mag. bal.    | 2           | 71          | No Change    | LED Relamp  | 2   | A19 LED, 9W             | 2            | 18          |
| 8                          | Fire Kitchen (Above Sink) | 1   | 4' 30w T8 Elec. bal.      | 1           | 28          | No Change    | LED Relamp  | 1   | 4' LED T8 2000 lu. 14W  | 1            | 14          |
| 9                          | Fire Break Room           | 5   | 4' 32w T8 EE Mag. bal.    | 2           | 71          | No Change    | LED Relamp  | 5   | 4' LED T8 2000 lu. 14W  | 2            | 28          |
| 10                         | Fire Back Stairwell       | 1   | 4' 40w T12 EE Mag. bal.   | 2           | 86          | No Change    | LED Relamp  | 1   | 8' LED T12/8 IS, 33W    | 2            | 66          |
| 11                         | Court Room                | 12  | 4' 32w T8 EE Mag. bal.    | 2           | 71          | No Change    | LED Relamp  | 12  | 4' LED T8 2000 lu. 14W  | 2            | 28          |
| 12                         | Gym                       | 15  | 4' 32w T8 EE Mag. bal.    | 2           | 71          | No Change    | LED Relamp  | 15  | 4' LED T8 2000 lu. 14W  | 2            | 28          |
| 13                         | Code Enforcement Lobby    | 6   | 4' 32w T8 EE Mag. bal.    | 2           | 71          | No Change    | LED Relamp  | 6   | 4' LED T8 2000 lu. 14W  | 2            | 28          |
| 14                         | Code Enforcement Office   | 25  | 4' 32w T8 EE Mag. bal.    | 2           | 71          | No Change    | LED Relamp  | 25  | 4' LED T8 2000 lu. 14W  | 2            | 28          |
| 15                         | Police Offices            | 15  | 2' 17w T8 Elec. bal.      | 3           | 47          | No Change    | LED Relamp  | 15  | 2' LED tube 1150 lu. 7W | 3            | 21          |
| 16                         | Police Offices            | 15  | 4' 32w T8 EE Mag. bal.    | 2           | 71          | No Change    | LED Relamp  | 15  | 4' LED T8 2000 lu. 14W  | 2            | 28          |


| Exterior Lighting Fixtures |            |     |                       |             |             |              |                                  |     |                        |              |             |
|----------------------------|------------|-----|-----------------------|-------------|-------------|--------------|----------------------------------|-----|------------------------|--------------|-------------|
| Existing Fixtures          |            |     |                       |             |             | Recommended  | Lighting Efficiency Improvements |     |                        |              |             |
| Line #                     | Area       | Qty | Present Lighting Type | Lamps /fixt | Watts /Fixt | Control Type | Measure Type                     | Qty | Proposed Lighting Type | Lamp s /fixt | Watts /Fixt |
| 1                          | South Face | 1   | LED wallpack, 50W     | 1           | 80          | Photocell    | No change                        | 1   | LED wallpack, 50W      | 1            | 80          |
| 2                          | West Face  | 1   | LED wallpack, 50W     | 1           | 80          | Photocell    | No change                        | 1   | LED wallpack, 50W      | 1            | 80          |

## Appendix B

### Energy Use and Cost Summary

| Energy       | Units Used  | BTU/unit | mmBTU      | % of total | kBtu/sq.ft./year |
|--------------|-------------|----------|------------|------------|------------------|
| Electricity  | 103,906 kwh | 3,412    | 355        | 37%        | 16.6             |
| Natural Gas  | 5,926 therm | 100,000  | 593        | 63%        | 27.7             |
| <b>Total</b> |             |          | <b>947</b> |            | <b>44.2</b>      |

| Cost         | Energy Cost      | Unit Costs     | % of total | \$/sq.ft./year |
|--------------|------------------|----------------|------------|----------------|
| Electricity  | \$ 11,154        | \$ 0.063 kwh   | 69%        | \$ 0.52        |
| Natural Gas  | \$ 4,947         | \$ 0.770 therm | 31%        | \$ 0.23        |
| <b>Total</b> | <b>\$ 16,102</b> |                |            | <b>\$ 0.75</b> |



**Energy Cost Index     \$ 0.75 /sf/yr.**

**Energy Use Intensity     44.2 kBtu/sf/yr.**

### Utility Bill Data

The following pages present the energy use and cost data for your facility and establish the value of each type of energy. Electricity is measured and billed in units of kilowatt-hours (kWh) that represent the total amount of electricity used in the billing period. Electricity may also be billed based on the highest rate of use, or peak demand, that occurred during the billing period. Electric demand is billed in units of kilowatts (kW).

Other fuels may be billed in volume units (gallons, hundred cubic feet or ccf, etc.) or based on their heat content (therms, equal to 100,000 British Thermal Units). All energy types may be converted into a common unit, such as BTUs, to facilitate analysis and comparison with other facilities. One million BTUs is abbreviated as mmBtu in this report.

# ELECTRICITY CONSUMPTION AND COST ANALYSIS

Village of Medina


Gross Area: 21,411 s.f.  
 16,558 Btu/s.f./Yr  
 \$ 0.52 /s.f.  
 1.4 watts/s.f.

Utility: National Grid  
 Account # ends w/ 0105  
 Rate: SC SC2D  
 Meter Charge: \$ 53.57 / month  
 Demand Charge: \$ 14.82 / kW  
 Supplier: National Grid

| Month Ending | Days | Usage          |              | Electricity Charges |                 | Total Electricity Cost | Demand Cost     | Energy \$/kWh   | Load Factor | Usage /day |
|--------------|------|----------------|--------------|---------------------|-----------------|------------------------|-----------------|-----------------|-------------|------------|
|              |      | Energy kWh     | Demand kW    | Utility Cost        | Supply Costs    |                        |                 |                 |             |            |
| 9/6/23       | 30   | 10,954         | 26.5         | \$ 483              | \$ 693          | \$ 1,176               | \$ 393          | \$ 0.067        | 0.57        | 365        |
| 10/4/23      | 28   | 8,192          | 27.8         | \$ 514              | \$ 432          | \$ 946                 | \$ 412          | \$ 0.059        | 0.44        | 293        |
| 11/3/23      | 30   | 6,776          | 26.9         | \$ 499              | \$ 351          | \$ 850                 | \$ 399          | \$ 0.059        | 0.35        | 226        |
| 12/6/23      | 33   | 7,503          | 14.7         | \$ 314              | \$ 396          | \$ 709                 | \$ 218          | \$ 0.058        | 0.64        | 227        |
| 1/5/24       | 30   | 7,360          | 16.5         | \$ 328              | \$ 328          | \$ 656                 | \$ 244          | \$ 0.049        | 0.62        | 245        |
| 2/5/24       | 31   | 7,803          | 18.6         | \$ 377              | \$ 639          | \$ 1,016               | \$ 276          | \$ 0.088        | 0.56        | 252        |
| 3/3/24       | 27   | 6,701          | 16.4         | \$ 342              | \$ 426          | \$ 768                 | \$ 243          | \$ 0.070        | 0.63        | 248        |
| 4/4/24       | 32   | 6,670          | 16.7         | \$ 357              | \$ 265          | \$ 622                 | \$ 247          | \$ 0.048        | 0.52        | 208        |
| 5/6/24       | 32   | 7,041          | 17.8         | \$ 357              | \$ 273          | \$ 630                 | \$ 264          | \$ 0.044        | 0.52        | 220        |
| 6/5/24       | 30   | 8,748          | 27.6         | \$ 471              | \$ 422          | \$ 893                 | \$ 409          | \$ 0.049        | 0.44        | 292        |
| 7/5/24       | 30   | 11,932         | 29.2         | \$ 498              | \$ 796          | \$ 1,294               | \$ 433          | \$ 0.068        | 0.57        | 398        |
| 8/6/24       | 32   | 14,226         | 27.7         | \$ 509              | \$ 1,084        | \$ 1,594               | \$ 410          | \$ 0.079        | 0.67        | 445        |
| <b>365</b>   |      | <b>103,906</b> | <b>266.4</b> | <b>\$ 5,048</b>     | <b>\$ 6,106</b> | <b>\$ 11,154</b>       | <b>\$ 3,948</b> | <b>\$ 0.063</b> | <b>0.54</b> | <b>285</b> |

Annual Energy: 103,906 kWh / year \$ 11,154 /year  
 Peak Demand: 29 kW Peak  
 Average Demand: 22 kW

Unit Costs  
 Demand \$ 14.82 \$/kW  
 Energy \$ 0.063 \$/kWh Incremental  
 Blended \$ 0.107 \$/kWh Blended



# NATURAL GAS CONSUMPTION AND COST ANALYSIS

Village of Medina


21,411 s.f.  
 27,676 Btu/s.f./Yr  
 \$ 0.23 /s.f.

Utility: **NYSEG**  
 Account # : ends w/ -599,  
 Rate: SC SC02  
 Billing unit: therm  
 BTU/Unit: **100,000**  
 Meter Charge: **\$ 32.00** / month  
 Supplier: **NYSEG**

## Natural Gas Use & Cost Summary:

| Month Ending | # Days | Utility Charges |          | Supplier Charges |          | Total Use therm | Total Natural Gas Cost | Average \$/therm |
|--------------|--------|-----------------|----------|------------------|----------|-----------------|------------------------|------------------|
|              |        | therm           | Cost     | therm            | Cost     |                 |                        |                  |
| 9/1/23       | 30     | 44              | \$ 44    | 44               | \$ 12    | 44              | \$ 56                  | \$ 0.54          |
| 10/4/23      | 33     | 202             | \$ 113   | 202              | \$ 54    | 202             | \$ 167                 | \$ 0.67          |
| 11/1/23      | 28     | 27              | \$ 36    | 27               | \$ 8     | 27              | \$ 44                  | \$ 0.45          |
| 12/5/23      | 34     | 1,135           | \$ 432   | 1,135            | \$ 465   | 1,135           | \$ 897                 | \$ 0.76          |
| 1/2/24       | 28     | 617             | \$ 318   | 617              | \$ 236   | 617             | \$ 553                 | \$ 0.85          |
| 2/5/24       | 34     | 1,492           | \$ 563   | 1,492            | \$ 541   | 1,492           | \$ 1,103               | \$ 0.72          |
| 3/4/24       | 28     | 1,114           | \$ 514   | 1,114            | \$ 387   | 1,114           | \$ 901                 | \$ 0.78          |
| 4/3/24       | 30     | 744             | \$ 354   | 744              | \$ 250   | 744             | \$ 604                 | \$ 0.77          |
| 5/3/24       | 30     | 388             | \$ 248   | 388              | \$ 118   | 388             | \$ 366                 | \$ 0.86          |
| 6/5/24       | 33     | 88              | \$ 104   | 88               | \$ 27    | 88              | \$ 131                 | \$ 1.13          |
| 7/3/24       | 28     | 28              | \$ 45    | 28               | \$ 10    | 28              | \$ 54                  | \$ 0.80          |
| 8/5/24       | 33     | 50              | \$ 55    | 50               | \$ 17    | 50              | \$ 72                  | \$ 0.81          |
|              | 369    | 5,926           | \$ 2,824 | 5,926            | \$ 2,123 | 5,926           | \$ 4,947               | \$ 0.77          |

Annual Natural Gas Cost **\$ 4,947 /year**  
 Annual Natural Gas Consumption **5,926 therm**  
 Average Unit Cost per therm: **\$ 0.770 \$ 7.70 / mmBtu**



## **Appendix C**

### **EEM Calculations**

#### Interactions

The Energy Efficiency Measure calculations in this section are stand-alone measures that are not interacted with the other calculations. Each measure shows the energy savings that may be expected if it is the only measure to be implemented. If multiple measures will be implemented, energy savings will likely be lower than the calculations represent.

As an example, replacing an 80% efficient boiler with a 92% efficient boiler will reduce the amount of fuel required to heat the building. If the walls and roof are insulated such that the required heating energy is reduced by 30%, the new boiler will serve a smaller heating load, and the energy savings gained from the boiler replacement will be reduced by 30%.

**CALCULATIONS FOR INTERIOR LIGHTING RETROFIT**  
**EEM-1 Village of Medina**

Type: Units: Unit cost: BTU/unit  
 Natural Gas therm \$ 0.770 100,000  
 Electricity kwh \$ 0.063 3,412  
 Demand kW \$ 14.82 12 Months of demand savings/year  
 80% of building is air conditioned

| HVAC Adjustment Factors |        |        |
|-------------------------|--------|--------|
| Cooling                 | Demand | Fuel   |
| HVACc                   | HVACd  | HVACg  |
| 9.00%                   | 20.00% | -2.00% |

| Existing Interior Lighting Systems |                           |     |                          |             | Recommended Lighting Controls |              |             |                  |                   | Recommended Interior Lighting Efficiency Improvements |              |     |                         |             |              |             |              |                |                 |                 |
|------------------------------------|---------------------------|-----|--------------------------|-------------|-------------------------------|--------------|-------------|------------------|-------------------|---|--------------|-----|-------------------------|-------------|--------------|-------------|--------------|----------------|-----------------|-----------------|
| Line #                             | Area                      | Qty | Present Lighting Type    | Lamps /fixt | Watts /Fixt                   | Control Type | % Reduction | Present Hrs./yr. | Proposed Hrs./yr. | # Controls required                                   | Measure Type | Qty | Proposed Lighting Type  | Lamps /fixt | Reflect or ? | Watts /Fixt | Project Cost | Annual Savings | kWh/yr. Savings | Payback (Years) |
| 1                                  | Fire Offices              | 2   | 4' 32w T8 EE Mag. bal.   | 2           | 71                            | No Change    | 0%          | 2,500            | 2,500             | 0   | LED Relamp   | 2   | 4' LED T8 2000 lu. 14W  | 2           |              | 28          | \$ 53        | \$ 29          | 215             | 1.8             |
| 2                                  | Fire Hall Hallways        | 8   | 4' 32w T8 EE Mag. bal.   | 2           | 71                            | No Change    | 0%          | 2,500            | 2,500             | 0   | LED Relamp   | 8   | 4' LED T8 2000 lu. 14W  | 2           |              | 28          | \$ 211       | \$ 115         | 860             | 1.8             |
| 3                                  | Fire Mop Closet           | 1   | 2' 17w T8 Elec. bal.     | 3           | 47                            | No Change    | 0%          | 2,500            | 2,500             | 0   | LED Relamp   | 1   | 2' LED tube 1150 lu. 7W | 3           |              | 21          | \$ 43        | \$ 9           | 65              | 5.0             |
| 4                                  | Fire Store Closet         | 1   | 4' 32w T8 EE Mag. bal.   | 3           | 110                           | No Change    | 0%          | 2,500            | 2,500             | 0   | LED Relamp   | 1   | 4' LED T8 2000 lu. 14W  | 3           |              | 42          | \$ 40        | \$ 23          | 170             | 1.7             |
| 5                                  | Fire Training Room        | 8   | 4' 32w T8 EE Mag. bal.   | 2           | 71                            | No Change    | 0%          | 2,500            | 2,500             | 0   | LED Relamp   | 8   | 4' LED T8 2000 lu. 14W  | 2           |              | 28          | \$ 211       | \$ 115         | 860             | 1.8             |
| 6                                  | Fire Kitchen (Pucks)      | 4   | 11w CFL Spiral Elec. bal | 1           | 11                            | No Change    | 0%          | 2,500            | 2,500             | 0   | LED Relamp   | 4   | 4' LED T8 2000 lu. 14W  | 1           |              | 14          | \$ 53        | (\$ 4)         | (30)            | (13.1)          |
| 7                                  | Fire Kitchen              | 2   | 4' 32w T8 EE Mag. bal.   | 2           | 71                            | No Change    | 0%          | 2,500            | 2,500             | 0   | LED Relamp   | 2   | A19 LED, 9W             | 2           |              | 18          | \$ 14        | \$ 36          | 265             | 0.4             |
| 8                                  | Fire Kitchen (Above Sink) | 1   | 4' 30w T8 Elec. bal.     | 1           | 28                            | No Change    | 0%          | 2,500            | 2,500             | 0   | LED Relamp   | 1   | 4' LED T8 2000 lu. 14W  | 1           |              | 14          | \$ 13        | \$ 5           | 35              | 2.8             |
| 9                                  | Fire Break Room           | 5   | 4' 32w T8 EE Mag. bal.   | 2           | 71                            | No Change    | 0%          | 2,500            | 2,500             | 0   | LED Relamp   | 5   | 4' LED T8 2000 lu. 14W  | 2           |              | 28          | \$ 132       | \$ 72          | 538             | 1.8             |
| 10                                 | Fire Back Stairwell       | 1   | 4' 40w T12 EE Mag. bal.  | 2           | 86                            | No Change    | 0%          | 2,500            | 2,500             | 0   | LED Relamp   | 1   | 8' LED T12/8 IS, 33W    | 2           |              | 66          | \$ 60        | \$ 7           | 50              | 8.9             |
| 11                                 | Court Room                | 12  | 4' 32w T8 EE Mag. bal.   | 2           | 71                            | No Change    | 0%          | 2,500            | 2,500             | 0   | LED Relamp   | 12  | 4' LED T8 2000 lu. 14W  | 2           |              | 28          | \$ 317       | \$ 173         | 1,290           | 1.8             |
| 12                                 | Gym                       | 15  | 4' 32w T8 EE Mag. bal.   | 2           | 71                            | No Change    | 0%          | 2,500            | 2,500             | 0   | LED Relamp   | 15  | 4' LED T8 2000 lu. 14W  | 2           |              | 28          | \$ 396       | \$ 216         | 1,613           | 1.8             |
| 13                                 | Code Enforcement Lobby    | 6   | 4' 32w T8 EE Mag. bal.   | 2           | 71                            | No Change    | 0%          | 2,500            | 2,500             | 0   | LED Relamp   | 6   | 4' LED T8 2000 lu. 14W  | 2           |              | 28          | \$ 158       | \$ 87          | 645             | 1.8             |
| 14                                 | Code Enforcement Offices  | 25  | 4' 32w T8 EE Mag. bal.   | 2           | 71                            | No Change    | 0%          | 2,500            | 2,500             | 0   | LED Relamp   | 25  | 4' LED T8 2000 lu. 14W  | 2           |              | 28          | \$ 660       | \$ 360         | 2,688           | 1.8             |
| 15                                 | Police Offices            | 15  | 2' 17w T8 Elec. bal.     | 3           | 47                            | No Change    | 0%          | 2,500            | 2,500             | 0   | LED Relamp   | 15  | 2' LED tube 1150 lu. 7W | 3           |              | 21          | \$ 648       | \$ 131         | 975             | 5.0             |
| 16                                 | Police Offices            | 15  | 4' 32w T8 EE Mag. bal.   | 2           | 71                            | No Change    | 0%          | 2,500            | 2,500             | 0   | LED Relamp   | 15  | 4' LED T8 2000 lu. 14W  | 2           |              | 28          | \$ 396       | \$ 216         | 1,613           | 1.8             |

121

8.0 kW existing

0

121

3.2 kW proposed

Note: bal. = ballast, EE = energy efficient, STD = standard efficiency, mag. = magnetic, Elec. = electronic, CFL = compact fluorescent lamp

| SUMMARY OF SAVINGS BY MEASURE TYPE: |              | Fixture Qty.              | Energy Savings    |                     | Demand     | Project Cost      | Electric Savings    | Payback (Years) | Measure Description |                                    |
|-------------------------------------|--------------|---------------------------|-------------------|---------------------|------------|-------------------|---------------------|-----------------|---------------------|------------------------------------|
|                                     | Measure Type |                           | Controls kwh/year | Efficiency kwh/year | kW Savings |                   |                     |                 |                     |                                    |
| C                                   | EEM-1C       | LED Relamp                | 121               | 0                   | 11,850     | 4.7               | \$ 3,406            | \$ 1,589        | 2.1                 | Screw-in or Socket based LED lamps |
|                                     |              | 121                       | 0                 | 11,850              | 4.7        | \$ 3,406          | \$ 1,589            |                 |                     |                                    |
|                                     |              | Gross Energy Savings      |                   | 11,850 kwh          |            |                   |                     |                 |                     |                                    |
|                                     |              | <b>Net Energy Savings</b> |                   | <b>12,703 kwh</b>   | <b>5.5</b> | <b>-254 therm</b> | <b>\$ 1,582 net</b> |                 |                     |                                    |

**PAYBACK PERIOD:**

Estimated Cost Interior Lighting: \$ 3,406 = 2.2 year payback  
 Annual Energy Savings (kWh + kW): \$ 1,582

# CALCULATIONS TO IMPLEMENT DEEPER SETBACK

## EEM-2 Village of Medina

INPUT DATA: 45% of Building to be Setback

|                         |            | Current | Proposed |                |
|-------------------------|------------|---------|----------|----------------|
| Heating T Setpoint:     | Occupied   | 66      | 66       | deg. F.        |
|                         | Unoccupied | 65      | 60       | deg. F.        |
| Cooling T Setpoint:     | Occupied   | 71      | 71       | deg. F.        |
|                         | Unoccupied | 75      | 80       | deg. F.        |
| HVAC Schedule           | Occupied   | 126.0   | 126.0    | Hours per week |
|                         | Unoccupied | 42.0    | 42.0     | Hours per week |
| Q internal gains:       | Occupied   | 26,146  | 26,146   | Btuh           |
|                         | Unoccupied | 10,072  | 10,072   | Btuh           |
| Q internal gains:       | Schedule   | 50      | 50       | Hours per week |
| BLC:<br>(excludes DOAS) | Occupied   | 2,035   | 2,035    | Btuh/deg. F.   |
|                         | Unoccupied | 1,214   | 1,214    | Btuh/deg. F.   |

**Fuel Data**

|                  |             |             |                     |
|------------------|-------------|-------------|---------------------|
|                  | Heating     | Cooling     |                     |
| Type:            | Natural Gas | Electricity | Economizer?         |
| Units:           | therm       | kwh         | No                  |
| Unit cost:       | \$ 0.770    | \$ 0.063    |                     |
| BTU/unit         | 100,000     | 3,412       |                     |
| Efficiency/ COP: | 84.2%       | 4.56        | Avg. COP. EER: 15.5 |

80.0% of bldg. is cooled

### CALCULATIONS:

| Current Rochester, 126 hrs./week |                |                  |                        |                          |                        |                    |
|----------------------------------|----------------|------------------|------------------------|--------------------------|------------------------|--------------------|
| Bin Mid Pt.                      | Occupied Hours | Unoccupied Hours | Occ Net Heat Loss BTUH | Unocc Net Heat Loss BTUH | Heating Fuel Use therm | Cooling Energy kwh |
| (7.5)                            | 3              | 0                | 133,465                | 77,755                   | 5                      | 0                  |
| (2.5)                            | 3              | 7                | 123,291                | 71,684                   | 10                     | 0                  |
| 2.5                              | 21             | 13               | 113,117                | 65,613                   | 38                     | 0                  |
| 7.5                              | 76             | 32               | 102,943                | 59,542                   | 116                    | 0                  |
| 12.5                             | 150            | 73               | 92,769                 | 53,471                   | 212                    | 0                  |
| 17.5                             | 293            | 89               | 82,595                 | 47,401                   | 338                    | 0                  |
| 22.5                             | 306            | 115              | 72,421                 | 41,330                   | 320                    | 0                  |
| 27.5                             | 315            | 141              | 62,247                 | 35,259                   | 292                    | 0                  |
| 32.5                             | 481            | 176              | 52,074                 | 29,188                   | 359                    | 0                  |
| 37.5                             | 721            | 250              | 41,900                 | 23,117                   | 428                    | 0                  |
| 42.5                             | 500            | 177              | 31,726                 | 17,047                   | 224                    | 0                  |
| 47.5                             | 372            | 177              | 21,552                 | 10,976                   | 118                    | 0                  |
| 52.5                             | 320            | 115              | 11,378                 | 4,905                    | 50                     | 0                  |
| 57.5                             | 491            | 244              | 1,204                  | 0                        | 7                      | 0                  |
| 62.5                             | 655            | 295              | 0                      | 0                        | 0                      | 0                  |
| 67.5                             | 621            | 199              | (9,815)                | (915)                    | 0                      | 323                |
| 72.5                             | 411            | 64               | (19,989)               | (6,986)                  | 0                      | 446                |
| 77.5                             | 480            | 19               | (30,163)               | (13,057)                 | 0                      | 758                |
| 82.5                             | 285            | 4                | (40,337)               | (19,127)                 | 0                      | 596                |
| 87.5                             | 57             | 0                | (50,511)               | (25,198)                 | 0                      | 148                |
| 92.5                             | 9              | 0                | (60,685)               | (31,269)                 | 0                      | 28                 |
| 97.5                             | 0              | 0                | (70,859)               | (37,340)                 | 0                      | 0                  |
| 102.5                            | 0              | 0                | (81,033)               | (43,411)                 | 0                      | 0                  |
| 107.5                            | 0              | 0                | (91,207)               | (49,481)                 | 0                      | 0                  |
| 8,760 hours                      |                |                  |                        |                          | 2,517                  | 2,299              |

| Proposed Rochester, 126 hrs./week |                |                  |                        |                          |                        |                    |
|-----------------------------------|----------------|------------------|------------------------|--------------------------|------------------------|--------------------|
| Bin Mid Pt.                       | Occupied Hours | Unoccupied Hours | Occ Net Heat Loss BTUH | Unocc Net Heat Loss BTUH | Heating Fuel Use therm | Cooling Energy kwh |
| (7.5)                             | 3              | 0                | 133,465                | 71,884                   | 5                      | 0                  |
| (2.5)                             | 3              | 7                | 123,291                | 65,813                   | 10                     | 0                  |
| 2.5                               | 21             | 13               | 113,117                | 59,742                   | 37                     | 0                  |
| 7.5                               | 76             | 32               | 102,943                | 53,671                   | 113                    | 0                  |
| 12.5                              | 150            | 73               | 92,769                 | 47,601                   | 207                    | 0                  |
| 17.5                              | 293            | 89               | 82,595                 | 41,530                   | 332                    | 0                  |
| 22.5                              | 306            | 115              | 72,421                 | 35,459                   | 312                    | 0                  |
| 27.5                              | 315            | 141              | 62,247                 | 29,388                   | 282                    | 0                  |
| 32.5                              | 481            | 176              | 52,074                 | 23,317                   | 346                    | 0                  |
| 37.5                              | 721            | 250              | 41,900                 | 17,247                   | 410                    | 0                  |
| 42.5                              | 500            | 177              | 31,726                 | 11,176                   | 212                    | 0                  |
| 47.5                              | 372            | 177              | 21,552                 | 5,105                    | 106                    | 0                  |
| 52.5                              | 320            | 115              | 11,378                 | 0                        | 43                     | 0                  |
| 57.5                              | 491            | 244              | 1,204                  | 0                        | 7                      | 0                  |
| 62.5                              | 655            | 295              | 0                      | 0                        | 0                      | 0                  |
| 67.5                              | 621            | 199              | (9,815)                | 0                        | 0                      | 314                |
| 72.5                              | 411            | 64               | (19,989)               | (966)                    | 0                      | 426                |
| 77.5                              | 480            | 19               | (30,163)               | (7,037)                  | 0                      | 752                |
| 82.5                              | 285            | 4                | (40,337)               | (13,107)                 | 0                      | 594                |
| 87.5                              | 57             | 0                | (50,511)               | (19,178)                 | 0                      | 148                |
| 92.5                              | 9              | 0                | (60,685)               | (25,249)                 | 0                      | 28                 |
| 97.5                              | 0              | 0                | (70,859)               | (31,320)                 | 0                      | 0                  |
| 102.5                             | 0              | 0                | (81,033)               | (37,391)                 | 0                      | 0                  |
| 107.5                             | 0              | 0                | (91,207)               | (43,461)                 | 0                      | 0                  |
| 8,760 hours                       |                |                  |                        |                          | 2,423                  | 2,263              |

|                  | Present | Proposed | Savings |       |
|------------------|---------|----------|---------|-------|
| Heating          | 2,517   | 2,423    | 94      | therm |
| Cooling          | 2,299   | 2,263    | 36      | kwh   |
| Annual Energy \$ |         |          | \$ 75   |       |

**IMPLEMENTATION COST & PAYBACK PERIOD:**

| Item                     | Material \$/unit | Labor \$/unit | Quantity | Total  |
|--------------------------|------------------|---------------|----------|--------|
| Thermostat Reprogramming | \$ 0             | \$ 200        | 2        | \$ 400 |
|                          |                  |               |          | \$ 400 |

Implementation Cost: \$ 400 = 5.4 year payback  
Annual Energy Savings: \$75



# CALCULATIONS TO INSULATE HEATING AND DOMESTIC HOT WATER PIPES

## EEM-3 Village of Medina

### Input Data

|                  |             |        |            |          |            |
|------------------|-------------|--------|------------|----------|------------|
| Fuel Information | Type:       | Units: | Unit cost: | BTU/unit | Efficiency |
| Heating System   | Natural Gas | therm  | \$ 0.770   | 100,000  | 86%        |
| DHW System       | Natural Gas | therm  | \$ 0.770   | 100,000  | 86%        |

|  | Type #1     | Type #2     | Type #3     |
|--|-------------|-------------|-------------|
| Fluid  | DHW         | DHW         | Hot Water   |
| Pipe Material                                      | Dull Copper | Dull Copper | Dull Copper |
| O.D., inches (d)                                   | 0.75        | 0.75        | 0.75        |
| Total Length, ft                                   | 8           | 8           | 10          |
| Fluid Temperature Inside Pipe, °F (Ts)             | 110         | 110         | 160         |
| Ambient Temperature, °F (Ta)                       | 65          | 65          | 65          |
| Annual Operating Hours                             | 8,760       | 8,760       | 1,413       |
| New Insulation Thickness, inches                   | 1.0         | 1.0         | 1.0         |
| Thermal Conductivity - "k" (Btu-in/hr-sq ft-°F)    | 0.250       | 0.250       | 0.250       |
| <b>Heat Loss - Bare Pipe</b>                       |             |             |             |
| C factor   | 1.016       | 1.016       | 1.016       |
| emissivity based on pipe material                  | 0.44        | 0.44        | 0.44        |
| Outside Radius Pipe, inches (Ri)                   | 0.38        | 0.38        | 0.38        |
| h convection, Btu/hr - s.f. pipe surface area - °F | 1.32        | 1.32        | 1.54        |
| h radiation, Btu/hr - s.f. pipe surface area - °F  | 0.50        | 0.50        | 0.57        |
| h total  | 1.81        | 1.81        | 2.11        |
| Pipe area, sq ft/lin ft of pipe                    | 0.196       | 0.196       | 0.196       |
| Q bare, Btu/hr-lin ft                              | 16          | 16          | 39          |
| <b>Heat Loss - Insulated Pipe</b>                  |             |             |             |
| Outside Radius Insulation, inches (Rs)             | 1.38        | 1.38        | 1.38        |
| Q i, Btu/hr-sq ft of outer area of insulation      | 6.3         | 6.3         | 13.3        |
| Insulation Area - sq ft/lin ft of pipe             | 0.7         | 0.7         | 0.7         |
| Q insul, Btu/hr-lin ft                             | 4.5         | 4.5         | 9.6         |
| <b>Avoided Energy Loss</b>                         |             |             |             |
| Existing Loss - mmBtu/year                         | 1.1         | 1.1         | 0.6         |
| <u>Proposed Loss - mmBtu/year</u>                  | 0.3         | 0.3         | 0.1         |
| Avoided Loss - mmBtu/year                          | 0.8         | 0.8         | 0.4         |
| <b>Annual Fuel Consumption</b>                     |             |             |             |
| existing   | 13          | 13          | 6           |
| proposed   | 4           | 4           | 2           |
| 24   | Units Saved | 9           | 9           |
| <u>Natural Gas</u>                                 | Fuel Type   | Natural Gas | Natural Gas |
| <b>\$ 18</b>                                       | \$/year     | <b>\$ 7</b> | <b>\$ 4</b> |

### Formulae:

Based on ASHRAE 1993 Fundamentals Handbook pages 20.9 and 22.17

$$h \text{ convection} = C \times \left\{ \left( \frac{1}{d} \right)^{0.2} \times \left\{ \left( \frac{1}{(Ts + Ta)/2} \right)^{0.181} \right\} \times \left\{ (Ts - Ta)^{0.266} \right\} \right\}$$

$$h \text{ radiation} = \left\{ \text{emissivity} \times 0.1713 \times 10^{-8} \times \left[ (Ta + 460)^4 - (Ts + 460)^4 \right] \right\} / (Ta - Ts)$$

$$Q \text{ bare} = h \text{ total} \times \text{Pipe Area} \times (Ts - Ta)$$

$$Q \text{ i} = (Ts - Ta) / \left\{ \left[ Rs \times \left( \ln \left( \frac{Rs}{Ri} \right) \right) \right] / k \right\}$$

$$Q \text{ insul} = Q \text{ i} \times \text{Insul Area}$$

$$\text{Total Avoided Consumption} = (Q \text{ bare} - Q \text{ insul}) \times \text{Total length of pipe} \times \text{Annual Operating Hours}$$

### Payback Period:

|                        |        |                    |
|------------------------|--------|--------------------|
| Implementation Cost:   | \$ 182 | = 10 years payback |
| Annual Energy Savings: | \$ 18  |                    |

# CALCULATIONS FOR BUILDING AIRFLOW REDUCTION

EEM-4 Village of Medina Village Hall

**INPUT DATA:**

| Proposed Reductions<br>Air changes/hour   | Air changes/Hour  |               |               | Proposed infiltration |             |           |
|---|-------------------|---------------|---------------|-----------------------|-------------|-----------|
|   | % reduction       | Proposed      | Period        | Cu. ft./hr.           | CFM         | btuh/deg. |
| Weatherstripping                          | 10%               | 0.27          | Occupied      | 67,127                | 1,119       | 1,208     |
| Weatherstripping                          | 10%               | 0.27          | Unoccupied    | 67,127                | 1,119       | 1,208     |
| <b>Total Infiltration &amp; Reduction</b> | <b>Occupied</b>   | <b>74,586</b> | <b>67,127</b> | <b>7,459</b>          | cfh savings |           |
| <b>Cu.Ft./hour</b>                        | <b>Unoccupied</b> | <b>74,586</b> | <b>67,127</b> | <b>7,459</b>          | cfh savings |           |

**CALCULATIONS:**

Leakage = 1/2 x Crack Length x Leakage Rate -or- ACH x Building Volume  
 Energy Savings = (Present Leakage - New Leakage) x Accum Hours x Temp Difference x CF2  
 Energy Cost Savings = (Energy Savings / CF1) x (Unit cost / Efficiency)

|                                       | Occupied | Unoccupied |   |
|---------------------------------------|----------|------------|---|
| T Setpoint:                           | 66       | 65         | °F  |
| Q internal gains:                     | 58,495   | 22,534     | Btuh  |
| BLC:                                  | 4,552    | 2,716      | Btuh/°F   |
| T Balance:                            | 53.3     | 56.5       | °F. T Balance = T Setpoint - (Q internal gains / BLC) |
| Bin Data for Rochester, 126 hrs./week |          |            |   |
| Accumulated Hours                     | 3,561    | 1,365      | below balance temp.                                   |
| Avg. OAT                              | 34.1     | 33.9       | °F below balance temp.                                |
| (T Set- Avg OAT)                      | 32.0     | 31.0       | °F difference   |

Type: Natural Gas  
 Units: therm  
 Unit cost: \$ 0.770 /therm  
 CF1 100,000 Btu/therm  
 Efficiency: 84.2%  
 CF2 0.018 Btu/hr-°F-cfh

|                            | Energy Use - Btu/year |            |             | Fuel Use   |
|----------------------------|-----------------------|------------|-------------|------------|
|                            | Occupied              | Unoccupied | Total       | therm / yr |
| Baseline infiltration rate | 153,211,900           | 56,719,200 | 209,931,100 | 2,495      |
| Proposed infiltration rate | 137,890,700           | 51,047,300 | 188,938,000 | 2,245      |

Total Savings 249 \$ 192

**IMPLEMENTATION COST & PAYBACK PERIOD:**

| Item                          | Matl. & Labor (\$ / lin ft) | Quantity (lin ft) | Total           |
|-------------------------------|-----------------------------|-------------------|-----------------|
| Door Weatherstripping         | \$ 3.00                     | 74                | \$ 222          |
| Garage Door Thresholds        | \$ 5.00                     | 50                | \$ 250          |
| Window Caulking               | \$ 2.00                     | 862               | \$ 1,724        |
| <b>Implementation Cost:</b>   |                             |                   | <b>\$ 2,196</b> |
| <b>Annual Energy Savings:</b> |                             |                   | <b>\$ 192</b>   |

= 11.4 year payback

**CALCULATIONS TO INSTALL INSULATED DOORS**  
**EEM-5 Village of Medina**

**INPUT DATA:**

|               |         |             |
|---------------|---------|-------------|
| Type & Qty.   | Man     | 2           |
|               | Present | Proposed    |
| Area:         | 42      | sq ft total |
| Perimeter:    | 40      | 40          |
| Infilt. rate: | 60      | 30          |
| R value:      | 1.0     | 5.0         |
| U factor:     | 1.000   | 0.200       |
| U x Area      | 42      | 8           |

|                   |         |          |               |
|-------------------|---------|----------|---------------|
|                   | Present | Proposed | Change        |
| Total UA          | 42      | 8        | 34 Btuh/deg F |
| Infiltration Load | 22      | 11       | 11 Btuh/deg F |
|                   | 64      | 19       | 44 Btuh/deg F |

**CALCULATIONS:**

|   |          |            |                  |             |             |
|---|----------|------------|------------------|-------------|-------------|
|   | Occupied | Unoccupied | Fuel Data        | Heating     | Cooling     |
| Heating Setpoint:                                 | 66       | 65         | Type:            | Natural Gas | Electricity |
| Cooling Setpoint:                                 | 71       | 75         | Units:           | therm       | kwh         |
| Q internal gains (Btuh):                          | 58,495   | 22,534     | Unit cost:       | \$ 0.770    | \$ 0.063    |
| BLC (Btuh/degree F):                              | 4,552    | 2,716      | BTU/unit         | 100,000     | 3,412       |
| T Balance (°F.):                                  | 53.3     | 56.5       | Efficiency/ COP: | 84.2%       | 293.1%      |
| T Balance = T Setpoint - (Q internal gains / BLC) |          |            | EER:             |             | 10.0        |

| Bin Mid-Pt. | Occupied Hours | Unoccupied Hours | Change in Occupied Heat Loss | Change in Unoccupied Heat Loss | Heating Savings therm | Cooling Savings kwh |
|-------------|----------------|------------------|------------------------------|--------------------------------|-----------------------|---------------------|
| (7.5)       | 3              | 0                | 3,271                        | 3,212                          | 0                     | 0                   |
| (2.5)       | 3              | 7                | 3,049                        | 2,990                          | 0                     | 0                   |
| 2.5         | 21             | 13               | 2,827                        | 2,768                          | 1                     | 0                   |
| 7.5         | 76             | 32               | 2,605                        | 2,546                          | 3                     | 0                   |
| 12.5        | 150            | 73               | 2,383                        | 2,324                          | 6                     | 0                   |
| 17.5        | 293            | 89               | 2,161                        | 2,102                          | 10                    | 0                   |
| 22.5        | 306            | 115              | 1,939                        | 1,880                          | 10                    | 0                   |
| 27.5        | 315            | 141              | 1,717                        | 1,658                          | 9                     | 0                   |
| 32.5        | 481            | 176              | 1,495                        | 1,436                          | 12                    | 0                   |
| 37.5        | 721            | 250              | 1,273                        | 1,214                          | 15                    | 0                   |
| 42.5        | 500            | 177              | 1,051                        | 992                            | 8                     | 0                   |
| 47.5        | 372            | 177              | 829                          | 770                            | 5                     | 0                   |
| 52.5        | 320            | 115              | 607                          | 548                            | 3                     | 0                   |
| 57.5        | 491            | 244              | 0                            | 0                              | 0                     | 0                   |
| 62.5        | 655            | 295              | 0                            | 0                              | 0                     | 0                   |
| 67.5        | 621            | 199              | 0                            | 0                              | 0                     | 0                   |
| 72.5        | 411            | 64               | (77)                         | 0                              | 0                     | 3                   |
| 77.5        | 480            | 19               | (299)                        | (109)                          | 0                     | 15                  |
| 82.5        | 285            | 4                | (521)                        | (331)                          | 0                     | 15                  |
| 87.5        | 57             | 0                | (743)                        | (553)                          | 0                     | 4                   |
| 92.5        | 9              | 0                | (965)                        | (775)                          | 0                     | 1                   |
| 97.5        | 0              | 0                | (1,187)                      | (997)                          | 0                     | 0                   |
| 102.5       | 0              | 0                | (1,409)                      | (1,219)                        | 0                     | 0                   |
| 107.5       | 0              | 0                | (1,631)                      | (1,441)                        | 0                     | 0                   |
|             | 8,760 hours    |                  |                              | Energy Savings:                | 83                    | 38                  |
|             |                |                  |                              |                                | \$ 64                 | \$ 2                |

**IMPLEMENTATION COST & PAYBACK PERIOD:**

| Item       | Material & Labor (\$ / each) | Quantity | Total  |
|------------|------------------------------|----------|--------|
| Man        | \$ 345                       | 2        | \$ 690 |
| Demolition | \$ 50                        | 2        | \$ 100 |

Implementation Cost: \$ 790 = 12 year payback  
Annual Energy Savings: \$ 66

**CALCULATIONS FOR EXTERIOR LIGHTING RETROFIT**  
**EEM-6 Village of Medina**

Electricity  
 Unit cost: \$ 0.063 /kwh  
 kW demand \$ 14.82  
 Months of demand savings: 0 months/year

| Existing Exterior Lighting Systems |            |     |                       |             |             | Recommended Lighting Controls |             |                  |                   |                     | Recommended Exterior Lighting Efficiency Improvements |     |                        |             |              |             |              |                |                 |                 |
|------------------------------------|------------|-----|-----------------------|-------------|-------------|-------------------------------|-------------|------------------|-------------------|---------------------|---|-----|------------------------|-------------|--------------|-------------|--------------|----------------|-----------------|-----------------|
| Line #                             | Area       | Qty | Present Lighting Type | Lamps /fixt | Watts /Fixt | Control Type                  | % Reduction | Present Hrs./yr. | Proposed Hrs./yr. | # Controls required | Measure Type  | Qty | Proposed Lighting Type | Lamps /fixt | Reflect or ? | Watts /Fixt | Project Cost | Annual Savings | kWh/yr. Savings | Payback (Years) |
| 1                                  | South Face | 1   | LED wallpack, 50W     | 1           | 80          | Photocell                     | 50%         | 3,833            | 1,916             | 1                   | No change   | 1   | LED wallpack, 50W      | 1           |              | 80          | \$ 150       | \$ 10          | 153             | 15.5            |
| 2                                  | West Face  | 1   | LED wallpack, 50W     | 1           | 80          | Photocell                     | 50%         | 3,833            | 1,916             | 1                   | No change   | 1   | LED wallpack, 50W      | 1           |              | 80          | \$ 150       | \$ 10          | 153             | 15.5            |
|                                    |            | 2   |                       |             | 0.2 kW      |                               |             |                  |                   | 2                   |   |     |                        |             | 0.2 kW       |             |              |                |                 |                 |

**SUMMARY OF SAVINGS BY MEASURE TYPE:**

| Measure Type | Fixture Qty. | Energy Savings    |                     | kW Reduction | Project Cost | Annual Savings | Payback (Years) | Measure Description |
|--------------|--------------|-------------------|---------------------|--------------|--------------|----------------|-----------------|---------------------|
|              |              | Controls kwh/year | Efficiency kwh/year |              |              |                |                 |                     |
| Photocell    | 2            | 307               | 0                   | 0.0          | \$ 300       | \$ 19          | 15.5            |                     |
|              |              | 0                 | 307                 | 0            | \$ 300       | \$ 19          | 15.5            |                     |

307 kwh

**PAYBACK PERIOD:**

Estimated Cost Exterior Lighting: \$ 300 = 15.5 year payback  
 Annual Energy Savings (kWh + kW): \$ 19

# CALCULATIONS TO INSULATE BUILDING ENVELOPE

## EEM-7 Village of Medina

### INPUT DATA:

|                          |                 |                  |                      |
|--------------------------|-----------------|------------------|----------------------|
| Surface to be insulated: | Fire Chief Wall |                  |                      |
| Area:                    | 200             | sq ft            |                      |
| Present R value:         | 10.0            |                  |                      |
| Revised R value:         | 20.0            |                  |                      |
| Present U factor::       | 0.100           | Btuh/sq ft-deg F |                      |
| Revised U factor:        | 0.050           | Btuh/sq ft-deg F |                      |
| Present U x Area         | 20              |                  | 20 UA Total present  |
| Proposed U x Area        | 10              |                  | 10 UA Total proposed |

### CALCULATIONS:

|   | Occupied | Unoccupied | Fuel Data        | Heating     | Cooling     |
|---|----------|------------|------------------|-------------|-------------|
| Heating Setpoint:                                 | 66       | 65         | Type:            | Natural Gas | Electricity |
| Cooling Setpoint:                                 | 71       | 75         | Units:           | therm       | kwh         |
| Q internal gains (Btuh):                          | 58,495   | 22,534     | Unit cost:       | \$ 0.770    | \$ 0.063    |
| BLC (Btuh/degree F):                              | 4,552    | 2,716      | BTU/unit         | 100,000     | 3,412       |
| T Balance (°F.):                                  | 53.3     | 56.5       | Efficiency/ COP: | 84.2%       | 293.1%      |
| T Balance = T Setpoint - (Q internal gains / BLC) |          |            | EER:             |             | 10.0        |

| Bin Mid-Pt. | Occupied Hours | Unoccupied Hours | Change in Occupied Heat Loss | Change in Unoccupied Heat Loss | Heating Savings therm | Cooling Savings kwh |
|-------------|----------------|------------------|------------------------------|--------------------------------|-----------------------|---------------------|
| (7.5)       | 3              | 0                | 737                          | 723                            | 0                     | 0                   |
| (2.5)       | 3              | 7                | 687                          | 673                            | 0                     | 0                   |
| 2.5         | 21             | 13               | 637                          | 623                            | 0                     | 0                   |
| 7.5         | 76             | 32               | 587                          | 573                            | 1                     | 0                   |
| 12.5        | 150            | 73               | 537                          | 523                            | 1                     | 0                   |
| 17.5        | 293            | 89               | 487                          | 473                            | 2                     | 0                   |
| 22.5        | 306            | 115              | 437                          | 423                            | 2                     | 0                   |
| 27.5        | 315            | 141              | 387                          | 373                            | 2                     | 0                   |
| 32.5        | 481            | 176              | 337                          | 323                            | 3                     | 0                   |
| 37.5        | 721            | 250              | 287                          | 273                            | 3                     | 0                   |
| 42.5        | 500            | 177              | 237                          | 223                            | 2                     | 0                   |
| 47.5        | 372            | 177              | 187                          | 173                            | 1                     | 0                   |
| 52.5        | 320            | 115              | 137                          | 123                            | 1                     | 0                   |
| 57.5        | 491            | 244              | 0                            | 0                              | 0                     | 0                   |
| 62.5        | 655            | 295              | 0                            | 0                              | 0                     | 0                   |
| 67.5        | 621            | 199              | 0                            | 0                              | 0                     | 0                   |
| 72.5        | 411            | 64               | (17)                         | 0                              | 0                     | 1                   |
| 77.5        | 480            | 19               | (67)                         | (25)                           | 0                     | 3                   |
| 82.5        | 285            | 4                | (117)                        | (75)                           | 0                     | 3                   |
| 87.5        | 57             | 0                | (167)                        | (125)                          | 0                     | 1                   |
| 92.5        | 9              | 0                | (217)                        | (175)                          | 0                     | 0                   |
| 97.5        | 0              | 0                | (267)                        | (225)                          | 0                     | 0                   |
| 102.5       | 0              | 0                | (317)                        | (275)                          | 0                     | 0                   |
| 107.5       | 0              | 0                | (367)                        | (325)                          | 0                     | 0                   |

8,760 hours

Energy Savings:

19 9  
\$ 14 \$ 1

### IMPLEMENTATION COST & PAYBACK PERIOD:

| Item            | Material & Labor (\$ / sq ft) | Quantity | Total  |
|-----------------|-------------------------------|----------|--------|
| Fire Chief Wall | \$ 1.18                       | 200      | \$ 236 |

Implementation Cost: \$ 236 = 15.9 year payback  
Annual Energy Savings: \$ 15

# CALCULATIONS TO INSTALL DOUBLE GLAZING

## EEM-8 Village of Medina

Type: Natural Gas  
 Units: **therm**  
 Unit cost: **\$ 0.770** /therm  
 Heat Content of Fuel: **100,000** Btu/therm  
 Combustion Efficiency: 84%

### DATA:

|   | Occupied      | Unoccupied    |               |
|---|---------------|---------------|---------------|
| T Setpoint:                                       | <b>66</b>     | <b>65</b>     | degrees F     |
| Q internal gains:                                 | <b>58,495</b> | <b>22,534</b> | Btuh          |
| BLC:  | <b>4,552</b>  | <b>2,716</b>  | Btuh/degree F |
| T Balance:  | 53.3          | 56.5          | degrees F     |
| T Balance = T Setpoint - (Q internal gains / BLC) |               |               |               |

### Glazing Information

| Firehouse Kitchen Window |                                |
|--------------------------|--------------------------------|
| Present Conditions       | Fixed Double Glazes            |
| Present Area:            | <b>36</b> sq ft                |
| U factor:                | <b>0.50</b> Btuh/sq ft-deg F   |
| Crack Length:            | 26 feet                        |
| Present Infiltration:    | 30 cfh                         |
| Proposed Condition       | Double glazed casement windows |
| Proposed Area:           | <b>36</b> sq ft                |
| New U factor:            | 0.28 Btuh/sq ft-deg F          |
| New Crack Length:        | 26 feet                        |
| Proposed Infiltration:   | 5 cfh                          |

### Bin Data for Rochester, 126 hrs./week

|            | T Setpoint | T Balance | Accum Hours  | Average O.A. Temp below T Balance | Temp Difference (T Set- Avg OAT) |
|------------|------------|-----------|--------------|-----------------------------------|----------------------------------|
| Occupied   | 66         | 53.3      | <b>3,561</b> | <b>34.1</b>                       | 32.0                             |
| Unoccupied | 65         | 56.5      | <b>1,365</b> | <b>33.9</b>                       | 31.0                             |

### CALCULATIONS:

Conduction Savings = (AreaPr x Upr) - (AreaRev x Urev + AreaInfill x Uinfill) x Accum Hours x Temp Differ  
 Infiltration Savings = 1/2 x 0.018 x {(LengthPr x lpr) - (Length Rev x lrev)} x Accum Hours x Temp Differenc  
 Energy Cost Savings = (Energy Savings / Conversion Factor) x (Unit cost / Efficiency)

| Winter          | Conduction Savings (Btu/year) | Infiltration Savings (Btu/year) | Total Savings (Btu/year) | Total Annual Fuel Savings (therm/year) | Energy Cost Savings (\$/year) |
|-----------------|-------------------------------|---------------------------------|--------------------------|--|-------------------------------|
| Occupied        | 904,000                       | 668,000                         | 1,572,000                | 19                                     | \$ 14                         |
| Unoccupied      | 335,000                       | 247,000                         | 582,000                  | 7                                      | \$ 5                          |
| Annual Savings: | 1,239,000                     | 915,000                         | 2,154,000                | 26                                     | \$ 20                         |

### IMPLEMENTATION COST & PAYBACK PERIOD:

| Item                          | Material & Labor \$ / sq. ft. | Quantity | Total         |
|-------------------------------|-------------------------------|----------|---------------|
| Vinyl Single Hung Windows     | \$ 26                         | 36       | \$ 938        |
| Removals                      | \$ 30                         | 2        | \$ 60         |
| <b>Implementation Cost:</b>   |                               |          | <b>\$ 998</b> |
| <b>Annual Energy Savings:</b> |                               |          | <b>\$ 20</b>  |

= 50.7 year payback

# CALCULATIONS TO INSTALL A TANKLESS WATER HEATER

EEM-9 Village of Medina

## INPUT DATA:

|                        | Present Fuel          | Proposed Fuel      |
|------------------------|-----------------------|--------------------|
| Fuel:                  | <b>Natural Gas</b>    | Electricity        |
| Units:                 | therm                 | kwh                |
| Fuel Cost:             | \$ 0.77 per therm     | \$ 0.06 per kwh    |
| BTU / unit:            | 100,000 Btu per therm | 3,412 Btu per kwh  |
| kW Demand cost:        | \$ 0.00 per kW        | \$ 14.82 per kW    |
| Average kW demand:     | <b>0.0</b> kW         | <b>0.0</b> kW      |
| Demand Diversity:      | <b>33%</b>            | <b>90%</b>         |
| Net kW Demand Savings: | - kW per month        | 0.0 kW per month   |
| Months of demand:      | <b>12</b> per year    | <b>12</b> per year |

## Annual DHW Consumption:

|                           | Present                   | Proposed           |
|---------------------------|---------------------------|--------------------|
| Hot Water Usage:          | <b>0.5</b> Gallons/person | 0.5 Gallons/person |
| Number of persons:        | <b>9</b> ( estimate)      | 9 ( estimate)      |
| Days of Usage:            | <b>250</b> per year       | 250 per year       |
| Hours of Usage per Day:   | 8 hours                   | 8 hours            |
| Average inlet water Temp: | 55 degrees F              | 55 degrees F       |
| Average hot water temp:   | 125 degrees F             | 125 degrees F      |

## Storage Tank Losses:

|                      | Present Tank     | Proposed Tank    |
|----------------------|------------------|------------------|
| Tank U factor:       | 0.15 Btu/SF/Hour | 0.15 Btu/SF/Hour |
| Height of Tank:      | 47.0 inches      | inches           |
| Diameter of Tank:    | 18.0 inches      | inches           |
|                      | 40 gallons/tank  | gallons/tank     |
| # of Tanks           | 1 Qty.           | 1 Qty.           |
| Hours Tank is Hot:   | 8,760 Hours      | 8,760            |
| Water Temperature:   | 125 Deg. F.      | 125              |
| Ambient Temperature: | 65 Deg. F.       | 65               |

## Recirculation Losses:

|                           |                         |
|---------------------------|-------------------------|
| 0.0% of boiler capacity = | 0 BTUh                  |
| 0 hours/year              | 8,760 hours/year = 100% |

## Boiler Jacket & Flue Losses:

|                        |                         |                         |
|------------------------|-------------------------|-------------------------|
| Burner Input           | 40,000 BTUH             | 40,000 BTUH             |
| COP:                   | <b>0.80</b>             | 2.50 COP                |
| Boiler Output Capacity | 32,000 BTU output       | 100,000 BTU output      |
| Jacket & Flue Losses:  | 0.5% of boiler capacity | 0.0% of boiler capacity |
| Boiler is Hot:         | 8,760 hours/year        | 8,760 hours/year = 100% |

## CALCULATIONS:

|                        | Present                   | Proposed                  |
|------------------------|---------------------------|---------------------------|
| Consumption Energy:    | 657,658 BTU output rqd/yr | 657,658 BTU output rqd/yr |
| Tank Energy Losses:    | 1,729,995 BTU/year        | 0 BTU/year                |
| Recirculation Losses:  | 0 BTU/year                | 0 BTU/year                |
| Boiler Jacket Losses:  | 1,401,600 BTU/year        | 0 BTU/year                |
| <b>Output BTU/Year</b> | <b>3,789,253</b>          | <b>657,658</b>            |

|                         |                           |                       |
|-------------------------|---------------------------|-----------------------|
| Annual Fuel Consumption | 47 therm                  | 77 kwh                |
| Demand                  | 0 billed kW /yr.          | 0 kW                  |
| Annual Fuel Cost        | \$ 36                     | \$ 11                 |
| <b>Annual Savings:</b>  | <b>47 therm</b>           | <b>\$ 25 per year</b> |
|                         | <b>(77) kwh</b>           |                       |
|                         | <b>(0) billed kW /yr.</b> |                       |

## IMPLEMENTATION COST & PAYBACK PERIOD:

| Item                          | Quantity | Matl. & Labor Cost | Total                       |
|-------------------------------|----------|--------------------|-----------------------------|
| Tankless Water Heater         | 1        | \$ 3,176           | \$ 3,176                    |
| <b>Implementation Cost:</b>   |          | <b>\$ 3,176</b>    | <b>= 124.8 year payback</b> |
| <b>Annual Energy Savings:</b> |          | <b>\$ 25</b>       |                             |

# CALCULATIONS TO SWITCH FUELS FOR HEATING WATER

EEM-10 Village of Medina

**INPUT DATA:**

|                        | Present Fuel          | Proposed Fuel      |
|------------------------|-----------------------|--------------------|
| Fuel:                  | <b>Natural Gas</b>    | Electricity        |
| Units:                 | therm                 | kwh                |
| Fuel Cost:             | \$ 0.77 per therm     | \$ 0.06 per kwh    |
| BTU / unit:            | 100,000 Btu per therm | 3,412 Btu per kwh  |
| kW Demand cost:        | \$ 0.00 per kW        | \$ 14.82 per kW    |
| Average kW demand:     | <b>0.0</b> kW         | <b>0.0</b> kW      |
| Demand Diversity:      | <b>33%</b>            | <b>90%</b>         |
| Net kW Demand Savings: | - kW per month        | 0.0 kW per month   |
| Months of demand:      | <b>12</b> per year    | <b>12</b> per year |

| Annual DHW Consumption:   | Present                   | Proposed           |
|---------------------------|---------------------------|--------------------|
| Hot Water Usage:          | <b>0.5</b> Gallons/person | 0.5 Gallons/person |
| Number of persons:        | <b>9</b> ( estimate)      | 9 ( estimate)      |
| Days of Usage:            | <b>250</b> per year       | 250 per year       |
| Hours of Usage per Day:   | 8 hours                   | 8 hours            |
| Average inlet water Temp: | 55 degrees F              | 55 degrees F       |
| Average hot water temp:   | 125 degrees F             | 125 degrees F      |

| Storage Tank Losses: | Present Tank     | Proposed Tank    |
|----------------------|------------------|------------------|
| Tank U factor:       | 0.15 Btu/SF/Hour | 0.15 Btu/SF/Hour |
| Height of Tank:      | inches           | inches           |
| Diameter of Tank:    | inches           | inches           |
|                      | gallons/tank     | gallons/tank     |
| # of Tanks           | 1 Qty.           | 1 Qty.           |
| Hours Tank is Hot:   | 8,760 Hours      | 8,760            |
| Water Temperature:   | 125 Deg. F.      | 125              |
| Ambient Temperature: | 65 Deg. F.       | 65               |

|                       |                           |                    |      |
|-----------------------|---------------------------|--------------------|------|
| Recirculation Losses: | 0.0% of boiler capacity = | 0 BTUh             |      |
|                       | 0 hours/year              | 8,760 hours/year = | 100% |

| Boiler Jacket & Flue Losses: |                         |                         |      |
|------------------------------|-------------------------|-------------------------|------|
| Burner Input                 | 40,000 BTUH             | 40,000 BTUH             |      |
| COP:                         | <b>0.80</b>             | 2.50 COP                |      |
| Boiler Output Capacity       | 32,000 BTU output       | 100,000 BTU output      |      |
| Jacket & Flue Losses:        | 0.5% of boiler capacity | 0.0% of boiler capacity |      |
| Boiler is Hot:               | 8,760 hours/year        | 8,760 hours/year =      | 100% |

**CALCULATIONS:**

|                         | Present                   | Proposed                  |
|-------------------------|---------------------------|---------------------------|
| Consumption Energy:     | 657,658 BTU output rqd/yr | 657,658 BTU output rqd/yr |
| Tank Energy Losses:     | 0 BTU/year                | 0 BTU/year                |
| Recirculation Losses:   | 0 BTU/year                | 0 BTU/year                |
| Boiler Jacket Losses:   | 1,401,600 BTU/year        | 0 BTU/year                |
| Output BTU/Year         | 2,059,258                 | 657,658                   |
| Annual Fuel Consumption | 26 therm                  | 77 kwh                    |
| Demand                  | 0 billed kW /yr.          | 0 kW                      |
| Annual Fuel Cost        | \$ 20                     | \$ 11                     |
| <b>Annual Savings:</b>  | <b>26 therm</b>           | <b>\$ 9 per year</b>      |
|                         | <b>(77) kwh</b>           |                           |
|                         | <b>(0) billed kW /yr.</b> |                           |

**IMPLEMENTATION COST & PAYBACK PERIOD:**

| Item                          | Quantity | Matl. & Labor Cost | Total                                |
|-------------------------------|----------|--------------------|--------------------------------------|
| Tankless Water Heater         | 1        | \$ 3,176           | \$ 3,176                             |
| <b>Implementation Cost:</b>   |          |                    | <b>\$ 3,176 = 361.2 year payback</b> |
| <b>Annual Energy Savings:</b> |          |                    | <b>\$ 9</b>                          |



# CALCULATIONS TO INSTALL CLEAN HEATING SYSTEM - AIR SOURCE HEAT PUMP

BE-1

Village of Medina

### Fuel Information

| Building Information               | Small Office |                | Heating             | Cooling       |
|------------------------------------|--------------|----------------|---------------------|---------------|
| Location                           | Buffalo      | Climate Zone 5 | Type: Natural Gas   | Electricity   |
| Portion of Building HP will serve: | 16%          |                | Units: therm        | kwh           |
| Building Heating Load (BHL)        | 53,665 BTU/h |                | Unit cost: \$ 0.770 | \$ 0.063 /kwh |
| Building Cooling Load (BCL)        | 33,005 BTU/h |                | BTU/unit 100,000    | 3,412 /kwh    |
| BEFLHheating                       | 1,413 Hours  |                | Heating Eff. 86%    | \$ 14.82 /kW  |
| BEFLHcooling                       | 713 Hours    |                | CO2 11.72           | 1.16 lbs/unit |

### Existing System

|  |   |
|--|---|
| Is baseline heating system electric?                   | N |
| Is baseline heating system fossil fuel?                | Y |
| If yes, will it remain in place in the efficient case? | N |

|  |   |
|--|---|
| Present Heating System                                     | Warm Air Furnace, Gas Fired < 225 kBtu/h            |
| Present Cooling System                                     | Air-cooled AC w/ other heat (≥ 65 and < 135 kBtu/h) |
| % of Portion to be served by ASHP that is presently cooled | 0%  |

### Proposed System

|  |  |                     |
|--|--|---------------------|
| Does proposed ASHP require supplemental resistance heat? | Y  |                     |
| ASHP Type  | Central Ducted                                     |                     |
| ASHP Application   | Whole (the ASHP will meet all of the heating load) |                     |
| Control Type   | Integrated/Modulating                              |                     |
| Heating Capacity   | 60,000 BTU/h at 5°F                                | 1.0 HP Sizing Ratio |
| Energy Efficiency Ratio                                  | 13.1 EER <sub>ee</sub>                             |                     |
| Seasonal Energy Efficiency Ratio                         | 15.0 SEER  |                     |
| Heating Season Performance Factor                        | 10.0 HSPF  |                     |

Resulting system to be modeled

### Scenario 1d

#### Central Ducted ASHP with Integrated/ Modulating controls sized to 100%

### Adjusted Efficiency Values

|                                | Baseline | Energy Efficient |                          |          |                |
|--------------------------------|----------|------------------|--------------------------|----------|----------------|
| SEER <sub>baseline</sub>       | 12.7     | 13.9             | EER <sub>season,ee</sub> | -1.670 c | cooling offset |
| EER <sub>baseline</sub>        | 11.0     | 13.1             | EER <sub>ee</sub>        | 1.041 d  | cooling slope  |
| COP <sub>season,baseline</sub> | 1.00     | 2.59             | COP <sub>season,ee</sub> | 0.081 a  | heating offset |
| FElecHeat                      | 0.00     | 1.00             | FElecHeat,new            | 0.876 b  | heating slope  |
| EFF <sub>baseline</sub>        | 0.86     | 1.00             | Fload,cooling            |          |                |
| FFuelHeat                      | 1.00     | 1.00             | Fload,heating            |          |                |
|                                |          | 1.00             | Fload,heating,FuelHeat   |          | 0.69 CF        |
|                                |          | 1.00             | Fload,heating,ElecHeat   |          |                |

|                                       | Baseline        | Energy Efficient | Savings          | Units        | Savings \$              | Savings CO2 Lbs/yr. |
|---------------------------------------|-----------------|------------------|------------------|--------------|-------------------------|---------------------|
| Cooling Electric Use (kWh/yr.)        | 0               | 1,687            | (1,687)          | kWh          |                         |                     |
| Heating Electric Use (kWh/yr.)        | 0               | 8,574            | (8,574)          | kWh          |                         |                     |
| <b>Total Electric Use (kWh/yr.)</b>   | <b>0</b>        | <b>10,261</b>    | <b>(10,261)</b>  | <b>kWh</b>   | <b>(\$ 646)</b>         | <b>(11,903)</b>     |
| Peak Demand (kW)                      | 0.0             | 1.7              | (1.7)            | kW           | (\$ 600)                |                     |
| Fossil Fuel Energy Use (MMBTU)        | 88              | 0                | 88               | MMBtu        |                         |                     |
| <b>Fossil Fuel Energy Use : therm</b> | <b>881</b>      | <b>0</b>         | <b>881</b>       | <b>therm</b> | <b>\$ 679</b>           | <b>10,331</b>       |
| <b>Annual Energy Costs</b>            | <b>\$ 679</b>   | <b>\$ 1,246</b>  | <b>(\$ 568)</b>  |              | <b>(\$ 568)</b>         | <b>(1,572)</b>      |
| <b>Estimated Project Cost</b>         | <b>\$ 2,950</b> | <b>per ton =</b> | <b>\$ 13,192</b> |              | <b>-23 year payback</b> |                     |

# Appendix D

## Assumptions/Data Used to Develop Energy and Dollar Savings Figures

### Building and Occupancy Information

|   |                    |                     |   |                  |    |   |      |  |  |
|---|--------------------|---------------------|---|------------------|----|---|------|--|--|
| Floor Area:   | 21,411 square feet | Avg. # of occupants | 9 | Heating Setpoint | 66 | Cooling Setpoint                                | 71   | % of base electricity use resulting in internal heat gains |  |
|   | days /occupied     | 9                   |   | 66               | 71 | days  | 100% |  |  |
|   | nights/unoccupied  | 0                   |   | 65               | 75 | nights  | 100% |  |  |
|   | # of computers     | 9                   |   |                  |    |   |      |  |  |
| Interior lighting, people and occupied levels of internal loads occur for |                    |                     |   | 50               |    | hours per week                                  |      |  |  |
| Electricity use at night is usually                                       |                    |                     |   | 40%              |    | of the usual electricity use during day periods |      |  |  |
| (This results in an average daytime kW that is                            |                    |                     |   | 90%              |    | of the peak metered kW)                         |      |  |  |

### Heating System Information

|  | % of bldg. served | COP heat    | EER   | Heat kBTUH               | Heating Fuel                             | Efficiency   |                          |
|--|-------------------|-------------|-------|--------------------------|--|--------------|--------------------------|
| Primary system: Forced Air   | 60%               | 0.80        | 10.00 | 548                      | Natural Gas                              | 84%          | Et                       |
| Secondary: Condensing Boiler   | 40%               | 0.95        | 10.00 | 167                      | Natural Gas                              | 92.0%        | Et                       |
| 80% of building is air conditioned   |                   |             |       |                          | Does the cooling system have economizer? | No           |                          |
| Describe the <u>direct outside air</u> or <u>central make-up air</u> system: |                   | Fuel        |       |                          |  |              |                          |
|  |                   | Natural Gas | 80%   | Eff.                     | 9.50                                     | EER for DOAS |                          |
|  |                   |             | 0     | cfm outside air, running |  |              |                          |
|  |                   |             | 0     | hours / week             |  | 0%           | heat recovery efficiency |

### Domestic Hot Water

|                        | Fuel        | Efficiency  |                                   |    |            |     |           |
|------------------------|-------------|-------------|-----------------------------------|----|------------|-----|-----------|
| DHW system energy type | Natural Gas | 80%         | Is there a pump to circulate DHW? | No |            |     |           |
| Hot Water usage is     | 0.5         | gallons per | person / day for                  | 9  | persons on | 250 | days/year |

### Weather & Schedule Information:

|  |               |       |            |          |                  |
|--|---------------|-------|------------|----------|------------------|
| Select nearest weather station for bin data: | ROCHESTER     |       |            | for TRM: | Buffalo          |
| Base temperature for heating degree days:    | 65 °F. yields | 6,664 | HDD base65 | for TRM: | Small Office     |
| Base temperature for cooling degree days:    | 70 °F. yields | 381   | CDD base70 | for TRM: | AC with Gas Heat |

### Present Schedule for Occupied/Day HVAC setpoints

| Day of week              | Start   | End      | Hours |
|--------------------------|---------|----------|-------|
| Sun 1                    | 4:00 AM | 10:00 PM | 18.0  |
| Mon 2                    | 4:00 AM | 10:00 PM | 18.0  |
| Tue 3                    | 4:00 AM | 10:00 PM | 18.0  |
| Wed 4                    | 4:00 AM | 10:00 PM | 18.0  |
| Thu 5                    | 4:00 AM | 10:00 PM | 18.0  |
| Fri 6                    | 4:00 AM | 10:00 PM | 18.0  |
| Sat 7                    | 4:00 AM | 10:00 PM | 18.0  |
| Rochester, 126 hrs./week |         |          | 126.0 |
|                          |         |          | 42.0  |

### Proposed Schedule for Occupied/Day HVAC setpoints

| Day of week              | Start   | End      | Hours |
|--------------------------|---------|----------|-------|
| 1                        | 4:00 AM | 10:00 PM | 18.0  |
| 2                        | 4:00 AM | 10:00 PM | 18.0  |
| 3                        | 4:00 AM | 10:00 PM | 18.0  |
| 4                        | 4:00 AM | 10:00 PM | 18.0  |
| 5                        | 4:00 AM | 10:00 PM | 18.0  |
| 6                        | 4:00 AM | 10:00 PM | 18.0  |
| 7                        | 4:00 AM | 10:00 PM | 18.0  |
| Rochester, 126 hrs./week |         |          | 126.0 |

## ESTIMATE OF BUILDING LOAD COEFFICIENT & TRUE-UP TO BILLED ENERGY USE

Village of Medina  
600 Main St  
Medina, NY 14103

### Building Information

|                            |                   |                     |                    |
|----------------------------|-------------------|---------------------|--------------------|
| Width (typical)            | 97 feet           | Building Floor Area | 21,411 sq. ft.     |
| Equivalent Length          | 171 feet          | Roof Area           | 8,313 sq. ft.      |
| Number of Floors           | 1.3 floors        | Gross Wall Area     | 15,736 sq. ft.     |
| Avg. Floor to Floor Height | 12 feet per floor | Building Volume     | 248,619 cubic feet |
| Roof or Ceiling rise is    | 4 feet in 12' run |                     |                    |

### Estimate of Conductive Heat Loss

| <u>Surface</u>              |               | <u>Area</u>   | <u>R-value</u> | <u>U Factor</u> | <u>U x A</u><br>Btuh/deg. F. | <u>% of BLC</u><br>w/o ventilation |
|-----------------------------|---------------|---------------|----------------|-----------------|------------------------------|------------------------------------|
| Roof                        | n/a           | 8,313         | 31.1           | 0.032           | 268                          | 10%                                |
| Walls                       | 91.4% of GWA  | 14,382        | 23.7           | 0.042           | 607                          | 22%                                |
| Town Hall                   | 2.7% of GWA   | 430           | 2.0            | 0.500           | 215                          | 8%                                 |
| Fire Hall                   | 1.6% of GWA   | 256           | 2.0            | 0.500           | 128                          | 5%                                 |
| Garage                      | 5 10x10 doors | 500           | 5.0            | 0.200           | 100                          | 4%                                 |
| Man                         | 8 3x7 doors   | 168           | 3.0            | 0.333           | 56                           | 2%                                 |
| Total Exterior Surface Area |               | 24,049 sq.ft. |                |                 | 1,374                        | 51%                                |

|                        |            | ACH   | equiv. cfm | Btuh/deg. F. | BLC (without ventilation)            |
|------------------------|------------|-------|------------|--------------|--------------------------------------|
| Est. Infiltration Rate | Occupied   | 0.30  | 1,243      | 1,343        | 2,716 Btuh/deg. F. Occupied          |
| Est. Infiltration Rate | Unoccupied | 0.30  | 1,243      | 1,343        | 2,716 Btuh/deg. F. Unoccupied        |
|                        |            | cfm   | Fraction   | Btuh/deg. F. | Total BLC with Ventilation           |
| Est. Ventilation Rate  | Occupied   | 1,700 | 100%       | 1,836        | <b>4,552 Btuh/deg. F. Occupied</b>   |
| Est. Ventilation Rate  | Unoccupied |       | 100%       | 0            | <b>2,716 Btuh/deg. F. Unoccupied</b> |

### Heat Gain Estimation

Estimated Solar Gain 0% of building heat loss during occupied periods will be met by solar gains

|                | kW          | # People | Total BTUH | Hours/wk. |
|----------------|-------------|----------|------------|-----------|
| Loads & People |             |          |            |           |
| Occupied       | <b>16.5</b> | <b>9</b> | 58,495     | 50.0      |
| Unoccupied     | <b>6.6</b>  | <b>0</b> | 22,534     | 118.0     |

**Heat Loss Study - continued**

Village of Medina  
600 Main St  
Medina, NY 14103

|                  |             |                     |             |
|------------------|-------------|---------------------|-------------|
| <b>Fuel Data</b> | Heating     | Cooling             | Economizer? |
| Type:            | Natural Gas | Electricity         | No          |
| Units:           | therm       | kwh                 |             |
| Unit cost:       | \$ 0.770    | \$ 0.063            |             |
| BTU/unit         | 100,000     | 3,412               |             |
| Nom. Eff, COP    | 0.860       | 2.931               | COP         |
| Avg. Eff, COP    | 0.842       | 4.56                | Avg. COP    |
|                  |             | 15.5                | Avg. EER    |
|                  |             | 80% of bldg. cooled |             |

|                     |            | Current |               |
|---------------------|------------|---------|---------------|
| Heating T Setpoint: | Occupied   | 66      | deg. F.       |
|                     | Unoccupied | 65      | deg. F.       |
| Cooling T Setpoint: | Occupied   | 71      | deg. F.       |
|                     | Unoccupied | 75      | deg. F.       |
| HVAC Schedule       | Occupied   | 126     | Hrs. per week |
|                     | Unoccupied | 42      | Hrs. per week |
| Q internal gains:   | Occupied   | 58,495  | Btuh          |
|                     | Unoccupied | 22,534  | Btuh          |
| Q internal gains:   | Schedule   | 50      | Hrs. per week |
| BLC:                | Occupied   | 4,552   | Btuh/deg. F.  |
|                     | Unoccupied | 2,716   | Btuh/deg. F.  |

|                     |
|---------------------|
| DOAS Energy Use     |
| 0 cfm               |
| 0% heat recov. Eff. |
| Heating Natural Gas |
| 100,000 Btu/therm   |
| 80% eff.            |
| 2.78 COP cool       |
| 0 hrs/week          |

| Current Rochester, 126 hrs./week |                |                  |                        |                          |                        |                    |               |                       |
|----------------------------------|----------------|------------------|------------------------|--------------------------|------------------------|--------------------|---------------|-----------------------|
| Bin Mid Pt.                      | Occupied Hours | Unoccupied Hours | Occ Net Heat Loss BTUH | Unocc Net Heat Loss BTUH | Heating Fuel Use therm | Cooling Energy kwh | DOAS Hours    | DOAS Heating kBtu/yr. |
| (7.5)                            | 3              | 0                | 298,602                | 173,961                  | 11                     | 0                  | 0             | 0                     |
| (2.5)                            | 3              | 7                | 275,840                | 160,379                  | 23                     | 0                  | 0             | 0                     |
| 2.5                              | 21             | 13               | 253,078                | 146,796                  | 86                     | 0                  | 0             | 0                     |
| 7.5                              | 76             | 32               | 230,316                | 133,214                  | 259                    | 0                  | 0             | 0                     |
| 12.5                             | 150            | 73               | 207,553                | 119,632                  | 474                    | 0                  | 0             | 0                     |
| 17.5                             | 293            | 89               | 184,791                | 106,050                  | 756                    | 0                  | 0             | 0                     |
| 22.5                             | 306            | 115              | 162,029                | 92,467                   | 716                    | 0                  | 0             | 0                     |
| 27.5                             | 315            | 141              | 139,267                | 78,885                   | 653                    | 0                  | 0             | 0                     |
| 32.5                             | 481            | 176              | 116,504                | 65,303                   | 803                    | 0                  | 0             | 0                     |
| 37.5                             | 721            | 250              | 93,742                 | 51,721                   | 957                    | 0                  | 0             | 0                     |
| 42.5                             | 500            | 177              | 70,980                 | 38,138                   | 502                    | 0                  | 0             | 0                     |
| 47.5                             | 372            | 177              | 48,218                 | 24,556                   | 265                    | 0                  | 0             | 0                     |
| 52.5                             | 320            | 115              | 25,455                 | 10,974                   | 112                    | 0                  | 0             | 0                     |
| 57.5                             | 491            | 244              | 2,693                  | 0                        | 16                     | 0                  | 0             | 0                     |
| 62.5                             | 655            | 295              | 0                      | 0                        | 0                      | 0                  | 0             | 0                     |
| 67.5                             | 621            | 199              | (50,088)               | (19,675)                 | 0                      | 1,578              | 0             | 0                     |
| 72.5                             | 411            | 64               | (86,227)               | (38,907)                 | 0                      | 1,840              | 0             | 0                     |
| 77.5                             | 480            | 19               | (112,161)              | (53,829)                 | 0                      | 2,875              | 0             | 0                     |
| 82.5                             | 285            | 4                | (150,360)              | (73,932)                 | 0                      | 2,451              | 0             | 0                     |
| 87.5                             | 57             | 0                | (192,274)              | (95,603)                 | 0                      | 677                | 0             | 0                     |
| 92.5                             | 9              | 0                | (206,279)              | (105,487)                | 0                      | 125                | 0             | 0                     |
| 97.5                             | 0              | 0                | (158,533)              | (83,540)                 | 0                      | 0                  | 0             | 0                     |
| 102.5                            | 0              | 0                | (181,296)              | (97,123)                 | 0                      | 0                  | 0             | 0                     |
| 107.5                            | 0              | 0                | (204,058)              | (110,705)                | 0                      | 0                  | 0             | 0                     |
| 8,760 hours                      |                |                  |                        |                          | 5,630                  | 9,546              | DOAS fuel use | 0                     |
|                                  |                |                  |                        |                          |                        |                    | DOAS cool use | 0                     |

**Cross Check Against Historic Consumption**

|                                    |           |            |                          |
|------------------------------------|-----------|------------|--------------------------|
| Present Annual Heating Fuel Use is | Historic  | Calculated | Difference               |
|                                    | 560 mmBTU | 563        | 100% of present fuel use |

## **Appendix E**

### **Clean Heating and Cooling Technology Overview**

#### **BENEFITS OF CLEAN HEATING AND COOLING (CHC) TECHNOLOGIES**

Commercial building owners are becoming increasingly aware of how their choice of HVAC system impacts bottom line operating costs and the environment. Most conventional heating systems either burn fuel or convert electricity into heat. CHC technologies, such as heat pumps, are different because they don't generate heat. Instead, they move existing heat energy from outside into your facility, which makes them more efficient since they deliver more heat energy than the electrical energy they consume.

There are many compelling reasons to install a CHC System in commercial buildings.

CHC systems:

- Can cost less to run than a traditional fossil fuel heating system.
- Integrate well with renewable and resilient building designs
- Offer the highest efficiency and most cost-effective space conditioning for HVAC
- Offer reduced maintenance costs because the exterior equipment is buried underground
- Offers flexible design and installation with many configurations available.
- Provides superior thermal comfort for all seasons.


## TYPES OF CLEAN HEATING AND COOLING (CHC) TECHNOLOGIES

### What is a Ground Source Heat Pump (GSHP)?

GSHP's are self-contained electrically powered systems that provide heating and cooling more efficiently than other types of conventional HVAC systems. This increase in efficiency is obtained due to the GSHP systems coupling with the earth's relatively stable ground temperature. For example, while the temperature of the outside air may vary drastically from summer to winter, the ground temperature remains relatively stable, making it an ideal heat "source" for heating and heat "sink" for cooling.

The GSHP system utilizes an electric vapor compression refrigeration cycle to exchange energy between the building load and a ground coupled loop. When in heating mode, energy is transferred from the low temperature ground loop source to the higher temperature heat sink (the load).


The system reverses during cooling, where the energy is absorbed by the ground loop.



Source: <https://www.epa.gov/rhc/geothermal-heating-and-cooling-technologies>

## What is an Air Source Heat Pump (ASHP)?


An air source heat pump works much like a refrigerator operating in reverse. Outside air is blown over a network of tubes filled with a refrigerant. This warms up the refrigerant, and it turns from a liquid into a gas. This gas passes through a compressor, which increases the pressure. Compression also adds more heat – similar to how the air hose warms up when you top up the air pressure in your tires. The compressed, hot gases pass into a heat exchanger, surrounded by cool air or water. The refrigerant transfers its heat to this cool air or water, making it warm. And this is circulated around your facility to provide heating and hot water. Meanwhile, the refrigerant condenses back into a cool liquid and starts the cycle all over again.



Source: <https://www.ways2gogreenblog.com/2017/10/18/a-brief-introduction-to-air-source-heat-pumps/>

## What is a Variable Refrigerant Flow (VRF)?

VRF systems use heat pumps or heat recovery systems to provide heating and cooling for all indoor and outdoor units without the use of air ducts. With a VRF system, your building will have multiple indoor units utilized by a single outdoor condensing unit, either with a heat pump or heat recovery system. A VRF HVAC system can heat and cool different zones or rooms within a building at the same time. If the appropriate VRF system is selected, building occupants have the ability to customize the temperature settings to their personal preferences. VRF equipment can be used in conjunction with a wide range of heating and cooling products. This means that a VRF system can be scaled to meet the climate control needs.



Source: [https://be-exchange.org/tech\\_primer/tech-primer-variable-refrigerant-flow-vrf-systems/](https://be-exchange.org/tech_primer/tech-primer-variable-refrigerant-flow-vrf-systems/)



## Appendix F

### Energy Savings Summaries

| Energy Efficiency Measures            |                |              |   | GHG           | Electric Savings |            |                       | Fuel Savings |                    |                   | \$ Savings & Cost    |                 |                        |
|---------------------------------------|----------------|--------------|---|---------------|------------------|------------|-----------------------|--------------|--------------------|-------------------|----------------------|-----------------|------------------------|
| EEM #                                 | Measure Status | EEM Category | EEM Description                               | CO2e Lbs./Yr. | kWh              | kW         | Electric Cost Savings | Fuel Type    | Fuel MMBtu Savings | Fuel Cost Savings | Total Annual Savings | Install Costs   | Simple Payback (years) |
| EEM-1                                 | R              | Lighting     | Interior Lighting Retrofit                    | 11,758        | 12,703           | 5.5        | \$ 1,778              | Natural Gas  | (25.4)             | (\$ 196)          | \$ 1,582             | \$ 3,406        | 2.2                    |
| EEM-2                                 | R              | Controls     | Implement Deeper Setback                      | 1,143         | 36               | 0.0        | \$ 2                  | Natural Gas  | 9.4                | \$ 72             | \$ 75                | \$ 400          | 5.4                    |
| EEM-3                                 | R              | HVAC         | Insulate Heating And Domestic Hot Water Pipes | 277           | 0                | 0.0        | (\$ 0)                | Natural Gas  | 2.4                | \$ 18             | \$ 18                | \$ 182          | 10.0                   |
| EEM-4                                 | R              | Envelope     | Building Airflow Reduction                    | 2,924         | 0                | 0.0        | \$ 0                  | Natural Gas  | 24.9               | \$ 192            | \$ 192               | \$ 2,196        | 11.4                   |
| EEM-5                                 | R              | Envelope     | Install Insulated Doors                       | 1,011         | 38               | 0.0        | \$ 2                  | Natural Gas  | 8.3                | \$ 64             | \$ 66                | \$ 790          | 12.0                   |
| EEM-6                                 | R              | Lighting     | Exterior Lighting Retrofit                    | 356           | 307              | 0.0        | \$ 19                 |              | 0.0                | \$ 0              | \$ 19                | \$ 300          | 15.5                   |
| EEM-7                                 | R              | Envelope     | Insulate Building Envelope                    | 228           | 9                | 0.0        | \$ 1                  | Natural Gas  | 1.9                | \$ 14             | \$ 15                | \$ 236          | 15.9                   |
| EEM-8                                 | RNE            | Envelope     | Install Double Glazing                        | 300           | 0                | 0.0        | \$ 0                  | Natural Gas  | 2.6                | \$ 20             | \$ 20                | \$ 998          | 50.7                   |
| EEM-9                                 | NR             | DHW          | Install A Tankless Water Heater               | 466           | (77)             | (0.0)      | (\$ 11)               | Natural Gas  | 4.7                | \$ 36             | \$ 25                | \$ 3,176        | 124.8                  |
| EEM-10                                | NR             | DHW          | Switch Fuels For Heating Water                | 212           | (77)             | (0.0)      | (\$ 11)               | Natural Gas  | 2.6                | \$ 20             | \$ 9                 | \$ 3,176        | 361.2                  |
| <b>Total of Recommended Measures:</b> |                |              |   | <b>17,995</b> | <b>13,092</b>    | <b>5.5</b> | <b>\$ 1,803</b>       |              | <b>24.0</b>        | <b>\$ 184</b>     | <b>\$ 1,987</b>      | <b>\$ 8,508</b> | <b>4.3</b>             |

| Building Electrification Measures     |                |              |   |               | Savings & Cost |            |                       |             |                    |                   |                      |               |                        |
|---------------------------------------|----------------|--------------|---|---------------|----------------|------------|-----------------------|-------------|--------------------|-------------------|----------------------|---------------|------------------------|
| EEM #                                 | Measure Status | EEM Category | Building Electrification Measure Descriptions       | CO2e Lbs./Yr. | kWh            | kW         | Electric Cost Savings | Fuel Type   | Fuel MMBtu Savings | Fuel Cost Savings | Total Annual Savings | Install Costs | Simple Payback (years) |
| BE-1                                  | NR             | ASHP         | Install Clean Heating System - Air Source Heat Pump | (1,572)       | (10,261)       | (1.7)      | (\$ 1,246)            | Natural Gas | 88.1               | \$ 679            | (\$ 568)             | \$ 13,192     | n/a                    |
| <b>Total of Recommended Measures:</b> |                |              |   | <b>0</b>      | <b>0</b>       | <b>0.0</b> | <b>\$ 0</b>           |             | <b>0.0</b>         | <b>\$ 0</b>       | <b>\$ 0</b>          | <b>\$ 0</b>   |                        |